

SUEZ Water New York Inc. - Mahopac  
Supplemental Sample Test Results - 1st Quarter 2021

Sample ID	Method	Analyte	Sample Date	Final	Units	MRL	MCL
Mahopac Well 1	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorobutanesulfonic acid	10/8/2020	3.9	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorodecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorododecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluoroheptanoic acid	10/8/2020	5.9	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorohexanesulfonic acid	10/8/2020	2.3	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorohexanoic acid	10/8/2020	7.4	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorononanoic acid	10/8/2020	2.4	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorooctanesulfonic acid	10/8/2020	20	ppt	2	10
Mahopac Well 1	EPA 537	Perfluorooctanoic acid	10/8/2020	22	ppt	2	10
Mahopac Well 1	EPA 537	Perfluorotetradecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorotridecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluoroundecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorobutanesulfonic acid	10/26/2020	4	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorodecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorododecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluoroheptanoic acid	10/26/2020	4.8	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorohexanesulfonic acid	10/26/2020	2.4	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorohexanoic acid	10/26/2020	7.1	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorononanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorooctanesulfonic acid	10/26/2020	11	ppt	2	10
Mahopac Well 1	EPA 537	Perfluorooctanoic acid	10/26/2020	13	ppt	2	10
Mahopac Well 1	EPA 537	Perfluorotetradecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorotridecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluoroundecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 1	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 1	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorobutanesulfonic acid	1/28/2021	4	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorodecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorododecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluoroheptanoic acid	1/28/2021	3.2	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorohexanesulfonic acid	1/28/2021	2.2	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorohexanoic acid	1/28/2021	5.2	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorononanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorooctanesulfonic acid	1/28/2021	ND	ppt	2	10
Mahopac Well 1	EPA 537	Perfluorooctanoic acid	1/28/2021	10	ppt	2	10
Mahopac Well 1	EPA 537	Perfluorotetradecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluorotridecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 1	EPA 537	Perfluoroundecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 1	EPA 522	1,4-Dioxane	1/29/2021	ND	ppb	0.07	1
Mahopac Well 1	EPA 522	1,4-Dioxane	10/8/2020	ND	ppb	0.07	1
Mahopac Well 2	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorobutanesulfonic acid	10/8/2020	6.2	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorodecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorododecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluoroheptanoic acid	10/8/2020	3.6	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorohexanesulfonic acid	10/8/2020	3.3	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorohexanoic acid	10/8/2020	5	ppt	2	NA

SUEZ Water New York Inc. - Mahopac  
Supplemental Sample Test Results - 1st Quarter 2021

Sample ID	Method	Analyte	Sample Date	Final	Units	MRL	MCL
Mahopac Well 2	EPA 537	Perfluorononanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorooctanesulfonic acid	10/8/2020	8.7	ppt	2	10
Mahopac Well 2	EPA 537	Perfluorooctanoic acid	10/8/2020	13	ppt	2	10
Mahopac Well 2	EPA 537	Perfluorotetradecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorotridecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluoroundecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorobutanesulfonic acid	10/26/2020	4.7	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorodecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorododecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluoroheptanoic acid	10/26/2020	3.3	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorohexanesulfonic acid	10/26/2020	2.8	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorohexanoic acid	10/26/2020	4.8	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorononanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorooctanesulfonic acid	10/26/2020	9.5	ppt	2	10
Mahopac Well 2	EPA 537	Perfluorooctanoic acid	10/26/2020	12	ppt	2	10
Mahopac Well 2	EPA 537	Perfluorotetradecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorotridecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluoroundecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 2	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 2	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorobutanesulfonic acid	1/28/2021	4.2	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorodecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorododecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluoroheptanoic acid	1/28/2021	2.5	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorohexanesulfonic acid	1/28/2021	2.5	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorohexanoic acid	1/28/2021	3.9	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorononanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorooctanesulfonic acid	1/28/2021	8.7	ppt	2	10
Mahopac Well 2	EPA 537	Perfluorooctanoic acid	1/28/2021	10	ppt	2	10
Mahopac Well 2	EPA 537	Perfluorotetradecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluorotridecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 2	EPA 537	Perfluoroundecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 2	EPA 522	1,4-Dioxane	10/8/2020	ND	ppb	0.07	1
Mahopac Well 2	EPA 522	1,4-Dioxane	1/28/2021	ND	ppb	0.07	1
Mahopac Well 3	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorobutanesulfonic acid	10/8/2020	6.4	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorodecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorododecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluoroheptanoic acid	10/8/2020	4.8	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorohexanesulfonic acid	10/8/2020	2.8	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorohexanoic acid	10/8/2020	7	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorononanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorooctanesulfonic acid	10/8/2020	11	ppt	2	10
Mahopac Well 3	EPA 537	Perfluorooctanoic acid	10/8/2020	15	ppt	2	10
Mahopac Well 3	EPA 537	Perfluorotetradecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorotridecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluoroundecanoic acid	10/8/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/26/2020	ND	ppt	2	NA

SUEZ Water New York Inc. - Mahopac  
Supplemental Sample Test Results - 1st Quarter 2021

Sample ID	Method	Analyte	Sample Date	Final	Units	MRL	MCL
Mahopac Well 3	EPA 537	Perfluorobutanesulfonic acid	10/26/2020	5.5	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorodecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorododecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluoroheptanoic acid	10/26/2020	4.5	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorohexanesulfonic acid	10/26/2020	2.5	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorohexanoic acid	10/26/2020	6.5	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorononanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorooctanesulfonic acid	10/26/2020	11	ppt	2	10
Mahopac Well 3	EPA 537	Perfluorooctanoic acid	10/26/2020	14	ppt	2	10
Mahopac Well 3	EPA 537	Perfluorotetradecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorotridecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluoroundecanoic acid	10/26/2020	ND	ppt	2	NA
Mahopac Well 3	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 3	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorobutanesulfonic acid	1/28/2021	5.6	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorodecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorododecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluoroheptanoic acid	1/28/2021	3.9	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorohexanesulfonic acid	1/28/2021	2.1	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorohexanoic acid	1/28/2021	5.5	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorononanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorooctanesulfonic acid	1/28/2021	ND	ppt	2	10
Mahopac Well 3	EPA 537	Perfluorooctanoic acid	1/28/2021	13	ppt	2	10
Mahopac Well 3	EPA 537	Perfluorotetradecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluorotridecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 3	EPA 537	Perfluoroundecanoic acid	1/28/2021	ND	ppt	2	NA
Mahopac Well 3	EPA 522	1,4-Dioxane	10/8/2020	ND	ppb	0.07	1
Mahopac Well 3	EPA 522	1,4-Dioxane	1/28/2021	ND	ppb	0.07	1

**List of Abbreviations:**

MRL = Method Reporting Limit, the lowest level the laboratory analysis method can reliably detect

MCL = Maximum Contaminant Level, the regulatory limit set by the State

NA = Not applicable

ND = Not detected

ppt= parts per trillion

ppb =parts per billion