

SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 15	EPA 522	1,4-Dioxane	10/2/2020	0	ppb	0.07	1
SW 15	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 15	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 15	EPA 537	Perfluorobutanesulfonic acid	10/2/2020	5.9	ppt	2	NA
SW 15	EPA 537	Perfluorodecanoic acid	10/2/2020	0	ppt	2	NA
SW 15	EPA 537	Perfluorododecanoic acid	10/2/2020	0	ppt	2	NA
SW 15	EPA 537	Perfluoroheptanoic acid	10/2/2020	4.2	ppt	2	NA
SW 15	EPA 537	Perfluorohexanesulfonic acid	10/2/2020	0	ppt	2	NA
SW 15	EPA 537	Perfluorohexanoic acid	10/2/2020	7.5	ppt	2	NA
SW 15	EPA 537	Perfluorononanoic acid	10/2/2020	0	ppt	2	NA
SW 15	EPA 537	Perfluorooctanesulfonic acid	10/2/2020	0	ppt	2	10
SW 15	EPA 537	Perfluorooctanoic acid	10/2/2020	9.1	ppt	2	10
SW 15	EPA 537	Perfluorotetradecanoic acid	10/2/2020	0	ppt	2	NA
SW 15	EPA 537	Perfluorotridecanoic acid	10/2/2020	0	ppt	2	NA
SW 15	EPA 537	Perfluoroundecanoic acid	10/2/2020	0	ppt	2	NA
SW 15	EPA 522	1,4-Dioxane	1/13/2021	0	ppb	0.07	1
SW 15	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 15	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorobutanesulfonic acid	1/13/2021	6.7	ppt	2	NA
SW 15	EPA 537	Perfluorodecanoic acid	1/13/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorododecanoic acid	1/13/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluoroheptanoic acid	1/13/2021	4.7	ppt	2	NA
SW 15	EPA 537	Perfluorohexanesulfonic acid	1/13/2021	2.4	ppt	2	NA
SW 15	EPA 537	Perfluorohexanoic acid	1/13/2021	6.9	ppt	2	NA
SW 15	EPA 537	Perfluorononanoic acid	1/13/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorooctanesulfonic acid	1/13/2021	2	ppt	2	10
SW 15	EPA 537	Perfluorooctanoic acid	1/13/2021	12	ppt	2	10
SW 15	EPA 537	Perfluorotetradecanoic acid	1/13/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorotridecanoic acid	1/13/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluoroundecanoic acid	1/13/2021	0	ppt	2	NA
SW 15	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	2/5/2021	0	ppt	2	NA
SW 15	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	2/5/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorobutanesulfonic acid	2/5/2021	5.5	ppt	2	NA
SW 15	EPA 537	Perfluorodecanoic acid	2/5/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorododecanoic acid	2/5/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluoroheptanoic acid	2/5/2021	4.2	ppt	2	NA
SW 15	EPA 537	Perfluorohexanesulfonic acid	2/5/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorohexanoic acid	2/5/2021	7.1	ppt	2	NA
SW 15	EPA 537	Perfluorononanoic acid	2/5/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorooctanesulfonic acid	2/5/2021	0	ppt	2	10
SW 15	EPA 537	Perfluorooctanoic acid	2/5/2021	8.1	ppt	2	10
SW 15	EPA 537	Perfluorotetradecanoic acid	2/5/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorotridecanoic acid	2/5/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluoroundecanoic acid	2/5/2021	0	ppt	2	NA
SW 15	EPA 522	1,4-Dioxane	4/14/2021	0	ppb	0.07	1
SW 15	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 15	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorobutanesulfonic acid	4/14/2021	5.5	ppt	2	NA
SW 15	EPA 537	Perfluorodecanoic acid	4/14/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorododecanoic acid	4/14/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluoroheptanoic acid	4/14/2021	4.8	ppt	2	NA
SW 15	EPA 537	Perfluorohexanesulfonic acid	4/14/2021	4	ppt	2	NA
SW 15	EPA 537	Perfluorohexanoic acid	4/14/2021	5.8	ppt	2	NA
SW 15	EPA 537	Perfluorononanoic acid	4/14/2021	2.9	ppt	2	NA
SW 15	EPA 537	Perfluorooctanesulfonic acid	4/14/2021	7.3	ppt	2	10
SW 15	EPA 537	Perfluorooctanoic acid	4/14/2021	17	ppt	2	10
SW 15	EPA 537	Perfluorotetradecanoic acid	4/14/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorotridecanoic acid	4/14/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluoroundecanoic acid	4/14/2021	0	ppt	2	NA
SW 15	EPA 522	1,4-Dioxane	4/28/2021	0	ppb	0.07	1
SW 15	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/28/2021	0	ppt	2	NA
SW 15	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/28/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorobutanesulfonic acid	4/28/2021	6.6	ppt	2	NA
SW 15	EPA 537	Perfluorodecanoic acid	4/28/2021	0	ppt	2	NA

SUEZ Water New York, Inc. - Rockland County  
 PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 15	EPA 537	Perfluorododecanoic acid	4/28/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluoroheptanoic acid	4/28/2021	4.7	ppt	2	NA
SW 15	EPA 537	Perfluorohexanesulfonic acid	4/28/2021	4.6	ppt	2	NA
SW 15	EPA 537	Perfluorohexanoic acid	4/28/2021	6	ppt	2	NA
SW 15	EPA 537	Perfluorononanoic acid	4/28/2021	2.9	ppt	2	NA
SW 15	EPA 537	Perfluorooctanesulfonic acid	4/28/2021	8.3	ppt	2	10
SW 15	EPA 537	Perfluorooctanoic acid	4/28/2021	17	ppt	2	10
SW 15	EPA 537	Perfluorotetradecanoic acid	4/28/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorotridecanoic acid	4/28/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluoroundecanoic acid	4/28/2021	0	ppt	2	NA
SW 15	EPA 522	1,4-Dioxane	7/8/2021	0	ppb	0.07	1
SW 15	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 15	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorobutanesulfonic acid	7/8/2021	6.6	ppt	2	NA
SW 15	EPA 537	Perfluorodecanoic acid	7/8/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorododecanoic acid	7/8/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluoroheptanoic acid	7/8/2021	5.5	ppt	2	NA
SW 15	EPA 537	Perfluorohexanesulfonic acid	7/8/2021	4.2	ppt	2	NA
SW 15	EPA 537	Perfluorohexanoic acid	7/8/2021	6.6	ppt	2	NA
SW 15	EPA 537	Perfluorononanoic acid	7/8/2021	3.3	ppt	2	NA
SW 15	EPA 537	Perfluorooctanesulfonic acid	7/8/2021	8.3	ppt	2	10
SW 15	EPA 537	Perfluorooctanoic acid	7/8/2021	18	ppt	2	10
SW 15	EPA 537	Perfluorotetradecanoic acid	7/8/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorotridecanoic acid	7/8/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluoroundecanoic acid	7/8/2021	0	ppt	2	NA
SW 15	EPA 522	1,4-Dioxane	11/4/2021	0	ppb	0.07	1
SW 15	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	11/4/2021	0	ppt	2	NA
SW 15	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	11/4/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorobutanesulfonic acid	11/4/2021	5	ppt	2	NA
SW 15	EPA 537	Perfluorodecanoic acid	11/4/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorododecanoic acid	11/4/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluoroheptanoic acid	11/4/2021	3.9	ppt	2	NA
SW 15	EPA 537	Perfluorohexanesulfonic acid	11/4/2021	2.6	ppt	2	NA
SW 15	EPA 537	Perfluorohexanoic acid	11/4/2021	4.4	ppt	2	NA
SW 15	EPA 537	Perfluorononanoic acid	11/4/2021	2.6	ppt	2	NA
SW 15	EPA 537	Perfluorooctanesulfonic acid	11/4/2021	6.1	ppt	2	10
SW 15	EPA 537	Perfluorooctanoic acid	11/4/2021	14	ppt	2	10
SW 15	EPA 537	Perfluorotetradecanoic acid	11/4/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluorotridecanoic acid	11/4/2021	0	ppt	2	NA
SW 15	EPA 537	Perfluoroundecanoic acid	11/4/2021	0	ppt	2	NA
SW 16	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/1/2020	0	ppt	2	NA
SW 16	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/1/2020	0	ppt	2	NA
SW 16	EPA 537	Perfluorobutanesulfonic acid	10/1/2020	4.4	ppt	2	NA
SW 16	EPA 537	Perfluorodecanoic acid	10/1/2020	0	ppt	2	NA
SW 16	EPA 537	Perfluorododecanoic acid	10/1/2020	0	ppt	2	NA
SW 16	EPA 537	Perfluoroheptanoic acid	10/1/2020	7.3	ppt	2	NA
SW 16	EPA 537	Perfluorohexanesulfonic acid	10/1/2020	8.8	ppt	2	NA
SW 16	EPA 537	Perfluorohexanoic acid	10/1/2020	11	ppt	2	NA
SW 16	EPA 537	Perfluorononanoic acid	10/1/2020	0	ppt	2	NA
SW 16	EPA 537	Perfluorooctanesulfonic acid	10/1/2020	8.6	ppt	2	10
SW 16	EPA 537	Perfluorooctanoic acid	10/1/2020	16	ppt	2	10
SW 16	EPA 537	Perfluorotetradecanoic acid	10/1/2020	0	ppt	2	NA
SW 16	EPA 537	Perfluorotridecanoic acid	10/1/2020	0	ppt	2	NA
SW 16	EPA 537	Perfluoroundecanoic acid	10/1/2020	0	ppt	2	NA
SW 16	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/14/2020	0	ppt	2	NA
SW 16	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/14/2020	0	ppt	2	NA
SW 16	EPA 537	Perfluorobutanesulfonic acid	10/14/2020	4.7	ppt	2	NA
SW 16	EPA 537	Perfluorodecanoic acid	10/14/2020	0	ppt	2	NA
SW 16	EPA 537	Perfluorododecanoic acid	10/14/2020	0	ppt	2	NA
SW 16	EPA 537	Perfluoroheptanoic acid	10/14/2020	7.4	ppt	2	NA
SW 16	EPA 537	Perfluorohexanesulfonic acid	10/14/2020	10	ppt	2	NA
SW 16	EPA 537	Perfluorohexanoic acid	10/14/2020	11	ppt	2	NA
SW 16	EPA 537	Perfluorononanoic acid	10/14/2020	0	ppt	2	NA
SW 16	EPA 537	Perfluorooctanesulfonic acid	10/14/2020	11	ppt	2	10

SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 16	EPA 537	Perfluorooctanoic acid	10/14/2020	16	ppt	2	10
SW 16	EPA 537	Perfluorotetradecanoic acid	10/14/2020	0	ppt	2	NA
SW 16	EPA 537	Perfluorotridecanoic acid	10/14/2020	0	ppt	2	NA
SW 16	EPA 537	Perfluoroundecanoic acid	10/14/2020	0	ppt	2	NA
SW 16	EPA 522	1,4-Dioxane	1/12/2021	0	ppb	0.07	1
SW 16	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/12/2021	0	ppt	2	NA
SW 16	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/12/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorobutanesulfonic acid	1/12/2021	4.1	ppt	2	NA
SW 16	EPA 537	Perfluorodecanoic acid	1/12/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorododecanoic acid	1/12/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluoroheptanoic acid	1/12/2021	8.6	ppt	2	NA
SW 16	EPA 537	Perfluorohexanesulfonic acid	1/12/2021	10	ppt	2	NA
SW 16	EPA 537	Perfluorohexanoic acid	1/12/2021	13	ppt	2	NA
SW 16	EPA 537	Perfluorononanoic acid	1/12/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorooctanesulfonic acid	1/12/2021	7.3	ppt	2	10
SW 16	EPA 537	Perfluorooctanoic acid	1/12/2021	17	ppt	2	10
SW 16	EPA 537	Perfluorotetradecanoic acid	1/12/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorotridecanoic acid	1/12/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluoroundecanoic acid	1/12/2021	0	ppt	2	NA
SW 16	EPA 522	1,4-Dioxane	4/14/2021	0	ppb	0.07	1
SW 16	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 16	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorobutanesulfonic acid	4/14/2021	4.8	ppt	2	NA
SW 16	EPA 537	Perfluorodecanoic acid	4/14/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorododecanoic acid	4/14/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluoroheptanoic acid	4/14/2021	10	ppt	2	NA
SW 16	EPA 537	Perfluorohexanesulfonic acid	4/14/2021	16	ppt	2	NA
SW 16	EPA 537	Perfluorohexanoic acid	4/14/2021	16	ppt	2	NA
SW 16	EPA 537	Perfluorononanoic acid	4/14/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorooctanesulfonic acid	4/14/2021	10	ppt	2	10
SW 16	EPA 537	Perfluorooctanoic acid	4/14/2021	18	ppt	2	10
SW 16	EPA 537	Perfluorotetradecanoic acid	4/14/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorotridecanoic acid	4/14/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluoroundecanoic acid	4/14/2021	0	ppt	2	NA
SW 16	EPA 522	1,4-Dioxane	7/8/2021	0	ppb	0.07	1
SW 16	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 16	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorobutanesulfonic acid	7/8/2021	4.7	ppt	2	NA
SW 16	EPA 537	Perfluorodecanoic acid	7/8/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorododecanoic acid	7/8/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluoroheptanoic acid	7/8/2021	5.5	ppt	2	NA
SW 16	EPA 537	Perfluorohexanesulfonic acid	7/8/2021	6.6	ppt	2	NA
SW 16	EPA 537	Perfluorohexanoic acid	7/8/2021	7.8	ppt	2	NA
SW 16	EPA 537	Perfluorononanoic acid	7/8/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorooctanesulfonic acid	7/8/2021	6.6	ppt	2	10
SW 16	EPA 537	Perfluorooctanoic acid	7/8/2021	15	ppt	2	10
SW 16	EPA 537	Perfluorotetradecanoic acid	7/8/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorotridecanoic acid	7/8/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluoroundecanoic acid	7/8/2021	0	ppt	2	NA
SW 16	EPA 522	1,4-Dioxane	10/5/2021	0	ppb	0.07	1
SW 16	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/5/2021	0	ppt	2	NA
SW 16	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/5/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorobutanesulfonic acid	10/5/2021	4.3	ppt	2	NA
SW 16	EPA 537	Perfluorodecanoic acid	10/5/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorododecanoic acid	10/5/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluoroheptanoic acid	10/5/2021	5.4	ppt	2	NA
SW 16	EPA 537	Perfluorohexanesulfonic acid	10/5/2021	6.4	ppt	2	NA
SW 16	EPA 537	Perfluorohexanoic acid	10/5/2021	7.3	ppt	2	NA
SW 16	EPA 537	Perfluorononanoic acid	10/5/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorooctanesulfonic acid	10/5/2021	6.8	ppt	2	10
SW 16	EPA 537	Perfluorooctanoic acid	10/5/2021	14	ppt	2	10
SW 16	EPA 537	Perfluorotetradecanoic acid	10/5/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluorotridecanoic acid	10/5/2021	0	ppt	2	NA
SW 16	EPA 537	Perfluoroundecanoic acid	10/5/2021	0	ppt	2	NA

SUEZ Water New York, Inc. - Rockland County  
 PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 17	EPA 522	1,4-Dioxane	10/1/2020	0	ppb	0.07	1
SW 17	EPA 522	1,4-Dioxane	10/2/2020	0.088	ppb	0.07	1
SW 17	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 17	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 17	EPA 537	Perfluorobutanesulfonic acid	10/2/2020	6.1	ppt	2	NA
SW 17	EPA 537	Perfluorodecanoic acid	10/2/2020	0	ppt	2	NA
SW 17	EPA 537	Perfluorododecanoic acid	10/2/2020	0	ppt	2	NA
SW 17	EPA 537	Perfluoroheptanoic acid	10/2/2020	4.3	ppt	2	NA
SW 17	EPA 537	Perfluorohexanesulfonic acid	10/2/2020	3.2	ppt	2	NA
SW 17	EPA 537	Perfluorohexanoic acid	10/2/2020	6.4	ppt	2	NA
SW 17	EPA 537	Perfluorononanoic acid	10/2/2020	4.3	ppt	2	NA
SW 17	EPA 537	Perfluorooctanesulfonic acid	10/2/2020	9	ppt	2	10
SW 17	EPA 537	Perfluorooctanoic acid	10/2/2020	14	ppt	2	10
SW 17	EPA 537	Perfluorotetradecanoic acid	10/2/2020	0	ppt	2	NA
SW 17	EPA 537	Perfluorotridecanoic acid	10/2/2020	0	ppt	2	NA
SW 17	EPA 537	Perfluoroundecanoic acid	10/2/2020	0	ppt	2	NA
SW 17	EPA 522	1,4-Dioxane	10/7/2020	0.076	ppb	0.07	1
SW 17	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/7/2020	0	ppt	2	NA
SW 17	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/7/2020	0	ppt	2	NA
SW 17	EPA 537	Perfluorobutanesulfonic acid	10/7/2020	5.9	ppt	2	NA
SW 17	EPA 537	Perfluorodecanoic acid	10/7/2020	0	ppt	2	NA
SW 17	EPA 537	Perfluorododecanoic acid	10/7/2020	0	ppt	2	NA
SW 17	EPA 537	Perfluoroheptanoic acid	10/7/2020	4.4	ppt	2	NA
SW 17	EPA 537	Perfluorohexanesulfonic acid	10/7/2020	3.2	ppt	2	NA
SW 17	EPA 537	Perfluorohexanoic acid	10/7/2020	6.1	ppt	2	NA
SW 17	EPA 537	Perfluorononanoic acid	10/7/2020	4.2	ppt	2	NA
SW 17	EPA 537	Perfluorooctanesulfonic acid	10/7/2020	9	ppt	2	10
SW 17	EPA 537	Perfluorooctanoic acid	10/7/2020	15	ppt	2	10
SW 17	EPA 537	Perfluorotetradecanoic acid	10/7/2020	0	ppt	2	NA
SW 17	EPA 537	Perfluorotridecanoic acid	10/7/2020	0	ppt	2	NA
SW 17	EPA 537	Perfluoroundecanoic acid	10/7/2020	0	ppt	2	NA
SW 17	EPA 522	1,4-Dioxane	1/13/2021	0	ppb	0.07	1
SW 17	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 17	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluorobutanesulfonic acid	1/13/2021	6.7	ppt	2	NA
SW 17	EPA 537	Perfluorodecanoic acid	1/13/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluorododecanoic acid	1/13/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluoroheptanoic acid	1/13/2021	3.8	ppt	2	NA
SW 17	EPA 537	Perfluorohexanesulfonic acid	1/13/2021	3.2	ppt	2	NA
SW 17	EPA 537	Perfluorohexanoic acid	1/13/2021	5.6	ppt	2	NA
SW 17	EPA 537	Perfluorononanoic acid	1/13/2021	3.8	ppt	2	NA
SW 17	EPA 537	Perfluorooctanesulfonic acid	1/13/2021	9.5	ppt	2	10
SW 17	EPA 537	Perfluorooctanoic acid	1/13/2021	13	ppt	2	10
SW 17	EPA 537	Perfluorotetradecanoic acid	1/13/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluorotridecanoic acid	1/13/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluoroundecanoic acid	1/13/2021	0	ppt	2	NA
SW 17	EPA 522	1,4-Dioxane	4/13/2021	0.073	ppb	0.07	1
SW 17	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/13/2021	0	ppt	2	NA
SW 17	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/13/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluorobutanesulfonic acid	4/13/2021	6.8	ppt	2	NA
SW 17	EPA 537	Perfluorodecanoic acid	4/13/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluorododecanoic acid	4/13/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluoroheptanoic acid	4/13/2021	4	ppt	2	NA
SW 17	EPA 537	Perfluorohexanesulfonic acid	4/13/2021	3	ppt	2	NA
SW 17	EPA 537	Perfluorohexanoic acid	4/13/2021	5.4	ppt	2	NA
SW 17	EPA 537	Perfluorononanoic acid	4/13/2021	3.1	ppt	2	NA
SW 17	EPA 537	Perfluorooctanesulfonic acid	4/13/2021	9	ppt	2	10
SW 17	EPA 537	Perfluorooctanoic acid	4/13/2021	14	ppt	2	10
SW 17	EPA 537	Perfluorotetradecanoic acid	4/13/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluorotridecanoic acid	4/13/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluoroundecanoic acid	4/13/2021	0	ppt	2	NA
SW 17	EPA 522	1,4-Dioxane	7/8/2021	0	ppb	0.07	1
SW 17	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 17	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA

SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 17	EPA 537	Perfluorobutanesulfonic acid	7/8/2021	6.5	ppt	2	NA
SW 17	EPA 537	Perfluorodecanoic acid	7/8/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluorododecanoic acid	7/8/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluoroheptanoic acid	7/8/2021	4	ppt	2	NA
SW 17	EPA 537	Perfluorohexanesulfonic acid	7/8/2021	3.1	ppt	2	NA
SW 17	EPA 537	Perfluorohexanoic acid	7/8/2021	6.1	ppt	2	NA
SW 17	EPA 537	Perfluorononanoic acid	7/8/2021	3.9	ppt	2	NA
SW 17	EPA 537	Perfluorooctanesulfonic acid	7/8/2021	9.3	ppt	2	10
SW 17	EPA 537	Perfluorooctanoic acid	7/8/2021	14	ppt	2	10
SW 17	EPA 537	Perfluorotetradecanoic acid	7/8/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluorotridecanoic acid	7/8/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluoroundecanoic acid	7/8/2021	0	ppt	2	NA
SW 19	EPA 522	1,4-Dioxane	10/2/2020	0	ppb	0.07	1
SW 19	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 19	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluorobutanesulfonic acid	10/2/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluorodecanoic acid	10/2/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluorododecanoic acid	10/2/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluoroheptanoic acid	10/2/2020	2	ppt	2	NA
SW 19	EPA 537	Perfluorohexanesulfonic acid	10/2/2020	3.2	ppt	2	NA
SW 19	EPA 537	Perfluorohexanoic acid	10/2/2020	2	ppt	2	NA
SW 19	EPA 537	Perfluorononanoic acid	10/2/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluorooctanesulfonic acid	10/2/2020	4.8	ppt	2	10
SW 19	EPA 537	Perfluorooctanoic acid	10/2/2020	13	ppt	2	10
SW 19	EPA 537	Perfluorotetradecanoic acid	10/2/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluorotridecanoic acid	10/2/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluoroundecanoic acid	10/2/2020	0	ppt	2	NA
SW 19	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/15/2020	0	ppt	2	NA
SW 19	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/15/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluorobutanesulfonic acid	10/15/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluorodecanoic acid	10/15/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluorododecanoic acid	10/15/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluoroheptanoic acid	10/15/2020	2.3	ppt	2	NA
SW 19	EPA 537	Perfluorohexanesulfonic acid	10/15/2020	3.3	ppt	2	NA
SW 19	EPA 537	Perfluorohexanoic acid	10/15/2020	2	ppt	2	NA
SW 19	EPA 537	Perfluorononanoic acid	10/15/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluorooctanesulfonic acid	10/15/2020	4.8	ppt	2	10
SW 19	EPA 537	Perfluorooctanoic acid	10/15/2020	13	ppt	2	10
SW 19	EPA 537	Perfluorotetradecanoic acid	10/15/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluorotridecanoic acid	10/15/2020	0	ppt	2	NA
SW 19	EPA 537	Perfluoroundecanoic acid	10/15/2020	0	ppt	2	NA
SW 19	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/12/2021	0	ppt	2	NA
SW 19	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/12/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorobutanesulfonic acid	1/12/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorodecanoic acid	1/12/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorododecanoic acid	1/12/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluoroheptanoic acid	1/12/2021	2.3	ppt	2	NA
SW 19	EPA 537	Perfluorohexanesulfonic acid	1/12/2021	3.3	ppt	2	NA
SW 19	EPA 537	Perfluorohexanoic acid	1/12/2021	2	ppt	2	NA
SW 19	EPA 537	Perfluorononanoic acid	1/12/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorooctanesulfonic acid	1/12/2021	5.1	ppt	2	10
SW 19	EPA 537	Perfluorooctanoic acid	1/12/2021	13	ppt	2	10
SW 19	EPA 537	Perfluorotetradecanoic acid	1/12/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorotridecanoic acid	1/12/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluoroundecanoic acid	1/12/2021	0	ppt	2	NA
SW 19	EPA 522	1,4-Dioxane	1/13/2021	0	ppb	0.07	1
SW 19	EPA 522	1,4-Dioxane	4/13/2021	0	ppb	0.07	1
SW 19	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/13/2021	0	ppt	2	NA
SW 19	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/13/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorobutanesulfonic acid	4/13/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorodecanoic acid	4/13/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorododecanoic acid	4/13/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluoroheptanoic acid	4/13/2021	2.3	ppt	2	NA
SW 19	EPA 537	Perfluorohexanesulfonic acid	4/13/2021	3.4	ppt	2	NA

SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 19	EPA 537	Perfluorohexanoic acid	4/13/2021	2	ppt	2	NA
SW 19	EPA 537	Perfluorononanoic acid	4/13/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorooctanesulfonic acid	4/13/2021	5.3	ppt	2	10
SW 19	EPA 537	Perfluorooctanoic acid	4/13/2021	14	ppt	2	10
SW 19	EPA 537	Perfluorotetradecanoic acid	4/13/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorotridecanoic acid	4/13/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluoroundecanoic acid	4/13/2021	0	ppt	2	NA
SW 19	EPA 522	1,4-Dioxane	7/7/2021	0	ppb	0.07	1
SW 19	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/7/2021	0	ppt	2	NA
SW 19	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/7/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorobutanesulfonic acid	7/7/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorodecanoic acid	7/7/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorododecanoic acid	7/7/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluoroheptanoic acid	7/7/2021	2.6	ppt	2	NA
SW 19	EPA 537	Perfluorohexanesulfonic acid	7/7/2021	3.5	ppt	2	NA
SW 19	EPA 537	Perfluorohexanoic acid	7/7/2021	8.7	ppt	2	NA
SW 19	EPA 537	Perfluorononanoic acid	7/7/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorooctanesulfonic acid	7/7/2021	5.6	ppt	2	10
SW 19	EPA 537	Perfluorooctanoic acid	7/7/2021	14	ppt	2	10
SW 19	EPA 537	Perfluorotetradecanoic acid	7/7/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorotridecanoic acid	7/7/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluoroundecanoic acid	7/7/2021	0	ppt	2	NA
SW 1A	EPA 522	1,4-Dioxane	10/2/2020	0.093	ppb	0.07	1
SW 1A	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 1A	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 1A	EPA 537	Perfluorobutanesulfonic acid	10/2/2020	4.6	ppt	2	NA
SW 1A	EPA 537	Perfluorodecanoic acid	10/2/2020	0	ppt	2	NA
SW 1A	EPA 537	Perfluorododecanoic acid	10/2/2020	0	ppt	2	NA
SW 1A	EPA 537	Perfluoroheptanoic acid	10/2/2020	3.8	ppt	2	NA
SW 1A	EPA 537	Perfluorohexanesulfonic acid	10/2/2020	2.6	ppt	2	NA
SW 1A	EPA 537	Perfluorohexanoic acid	10/2/2020	5.1	ppt	2	NA
SW 1A	EPA 537	Perfluorononanoic acid	10/2/2020	2	ppt	2	NA
SW 1A	EPA 537	Perfluorooctanesulfonic acid	10/2/2020	7.2	ppt	2	10
SW 1A	EPA 537	Perfluorooctanoic acid	10/2/2020	14	ppt	2	10
SW 1A	EPA 537	Perfluorotetradecanoic acid	10/2/2020	0	ppt	2	NA
SW 1A	EPA 537	Perfluorotridecanoic acid	10/2/2020	0	ppt	2	NA
SW 1A	EPA 537	Perfluoroundecanoic acid	10/2/2020	0	ppt	2	NA
SW 1A	EPA 522	1,4-Dioxane	10/7/2020	0.074	ppb	0.07	1
SW 1A	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/7/2020	0	ppt	2	NA
SW 1A	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/7/2020	0	ppt	2	NA
SW 1A	EPA 537	Perfluorobutanesulfonic acid	10/7/2020	4.6	ppt	2	NA
SW 1A	EPA 537	Perfluorodecanoic acid	10/7/2020	0	ppt	2	NA
SW 1A	EPA 537	Perfluorododecanoic acid	10/7/2020	0	ppt	2	NA
SW 1A	EPA 537	Perfluoroheptanoic acid	10/7/2020	3.8	ppt	2	NA
SW 1A	EPA 537	Perfluorohexanesulfonic acid	10/7/2020	2.8	ppt	2	NA
SW 1A	EPA 537	Perfluorohexanoic acid	10/7/2020	5.1	ppt	2	NA
SW 1A	EPA 537	Perfluorononanoic acid	10/7/2020	2	ppt	2	NA
SW 1A	EPA 537	Perfluorooctanesulfonic acid	10/7/2020	7.4	ppt	2	10
SW 1A	EPA 537	Perfluorooctanoic acid	10/7/2020	14	ppt	2	10
SW 1A	EPA 537	Perfluorotetradecanoic acid	10/7/2020	0	ppt	2	NA
SW 1A	EPA 537	Perfluorotridecanoic acid	10/7/2020	0	ppt	2	NA
SW 1A	EPA 537	Perfluoroundecanoic acid	10/7/2020	0	ppt	2	NA
SW 1A	EPA 522	1,4-Dioxane	1/12/2021	0	ppb	0.07	1
SW 1A	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 1A	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorobutanesulfonic acid	1/13/2021	4.3	ppt	2	NA
SW 1A	EPA 537	Perfluorodecanoic acid	1/13/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorododecanoic acid	1/13/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluoroheptanoic acid	1/13/2021	3.4	ppt	2	NA
SW 1A	EPA 537	Perfluorohexanesulfonic acid	1/13/2021	2.7	ppt	2	NA
SW 1A	EPA 537	Perfluorohexanoic acid	1/13/2021	4.7	ppt	2	NA
SW 1A	EPA 537	Perfluorononanoic acid	1/13/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorooctanesulfonic acid	1/13/2021	7.4	ppt	2	10
SW 1A	EPA 537	Perfluorooctanoic acid	1/13/2021	13	ppt	2	10

SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 1A	EPA 537	Perfluorotetradecanoic acid	1/13/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorotridecanoic acid	1/13/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluoroundecanoic acid	1/13/2021	0	ppt	2	NA
SW 1A	EPA 522	1,4-Dioxane	4/14/2021	0.072	ppb	0.07	1
SW 1A	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 1A	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorobutanesulfonic acid	4/14/2021	3.9	ppt	2	NA
SW 1A	EPA 537	Perfluorodecanoic acid	4/14/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorododecanoic acid	4/14/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluoroheptanoic acid	4/14/2021	3.3	ppt	2	NA
SW 1A	EPA 537	Perfluorohexanesulfonic acid	4/14/2021	2.7	ppt	2	NA
SW 1A	EPA 537	Perfluorohexanoic acid	4/14/2021	4.5	ppt	2	NA
SW 1A	EPA 537	Perfluorononanoic acid	4/14/2021	2	ppt	2	NA
SW 1A	EPA 537	Perfluorooctanesulfonic acid	4/14/2021	7.6	ppt	2	10
SW 1A	EPA 537	Perfluorooctanoic acid	4/14/2021	13	ppt	2	10
SW 1A	EPA 537	Perfluorotetradecanoic acid	4/14/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorotridecanoic acid	4/14/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluoroundecanoic acid	4/14/2021	0	ppt	2	NA
SW 1A	EPA 522	1,4-Dioxane	7/8/2021	0	ppb	0.07	1
SW 1A	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 1A	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorobutanesulfonic acid	7/8/2021	4.8	ppt	2	NA
SW 1A	EPA 537	Perfluorodecanoic acid	7/8/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorododecanoic acid	7/8/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluoroheptanoic acid	7/8/2021	3.6	ppt	2	NA
SW 1A	EPA 537	Perfluorohexanesulfonic acid	7/8/2021	2.6	ppt	2	NA
SW 1A	EPA 537	Perfluorohexanoic acid	7/8/2021	5.6	ppt	2	NA
SW 1A	EPA 537	Perfluorononanoic acid	7/8/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorooctanesulfonic acid	7/8/2021	7.5	ppt	2	10
SW 1A	EPA 537	Perfluorooctanoic acid	7/8/2021	13	ppt	2	10
SW 1A	EPA 537	Perfluorotetradecanoic acid	7/8/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorotridecanoic acid	7/8/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluoroundecanoic acid	7/8/2021	0	ppt	2	NA
SW 20	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/1/2020	0	ppt	2	NA
SW 20	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/1/2020	0	ppt	2	NA
SW 20	EPA 537	Perfluorobutanesulfonic acid	10/1/2020	5	ppt	2	NA
SW 20	EPA 537	Perfluorodecanoic acid	10/1/2020	0	ppt	2	NA
SW 20	EPA 537	Perfluorododecanoic acid	10/1/2020	0	ppt	2	NA
SW 20	EPA 537	Perfluoroheptanoic acid	10/1/2020	7.8	ppt	2	NA
SW 20	EPA 537	Perfluorohexanesulfonic acid	10/1/2020	28	ppt	2	NA
SW 20	EPA 537	Perfluorohexanoic acid	10/1/2020	14	ppt	2	NA
SW 20	EPA 537	Perfluorononanoic acid	10/1/2020	0	ppt	2	NA
SW 20	EPA 537	Perfluorooctanesulfonic acid	10/1/2020	47	ppt	2	10
SW 20	EPA 537	Perfluorooctanoic acid	10/1/2020	11	ppt	2	10
SW 20	EPA 537	Perfluorotetradecanoic acid	10/1/2020	0	ppt	2	NA
SW 20	EPA 537	Perfluorotridecanoic acid	10/1/2020	0	ppt	2	NA
SW 20	EPA 537	Perfluoroundecanoic acid	10/1/2020	0	ppt	2	NA
SW 20	EPA 522	1,4-Dioxane	1/12/2021	0	ppb	0.07	1
SW 20	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/12/2021	0	ppt	2	NA
SW 20	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/12/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorobutanesulfonic acid	1/12/2021	3.8	ppt	2	NA
SW 20	EPA 537	Perfluorodecanoic acid	1/12/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorododecanoic acid	1/12/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluoroheptanoic acid	1/12/2021	5.4	ppt	2	NA
SW 20	EPA 537	Perfluorohexanesulfonic acid	1/12/2021	20	ppt	2	NA
SW 20	EPA 537	Perfluorohexanoic acid	1/12/2021	9.7	ppt	2	NA
SW 20	EPA 537	Perfluorononanoic acid	1/12/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorooctanesulfonic acid	1/12/2021	32	ppt	2	10
SW 20	EPA 537	Perfluorooctanoic acid	1/12/2021	8.9	ppt	2	10
SW 20	EPA 537	Perfluorotetradecanoic acid	1/12/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorotridecanoic acid	1/12/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluoroundecanoic acid	1/12/2021	0	ppt	2	NA
SW 20	EPA 522	1,4-Dioxane	1/13/2021	0.08	ppb	0.07	1
SW 20	EPA 522	1,4-Dioxane	4/14/2021	0	ppb	0.07	1

SUEZ Water New York, Inc. - Rockland County  
 PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 20	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 20	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorobutanesulfonic acid	4/14/2021	4.4	ppt	2	NA
SW 20	EPA 537	Perfluorodecanoic acid	4/14/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorododecanoic acid	4/14/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluoroheptanoic acid	4/14/2021	6.8	ppt	2	NA
SW 20	EPA 537	Perfluorohexanesulfonic acid	4/14/2021	24	ppt	2	NA
SW 20	EPA 537	Perfluorohexanoic acid	4/14/2021	12	ppt	2	NA
SW 20	EPA 537	Perfluorononanoic acid	4/14/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorooctanesulfonic acid	4/14/2021	40	ppt	2	10
SW 20	EPA 537	Perfluorooctanoic acid	4/14/2021	10	ppt	2	10
SW 20	EPA 537	Perfluorotetradecanoic acid	4/14/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorotridecanoic acid	4/14/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluoroundecanoic acid	4/14/2021	0	ppt	2	NA
SW 20	EPA 522	1,4-Dioxane	7/8/2021	0	ppb	0.07	1
SW 20	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 20	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorobutanesulfonic acid	7/8/2021	4.4	ppt	2	NA
SW 20	EPA 537	Perfluorodecanoic acid	7/8/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorododecanoic acid	7/8/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluoroheptanoic acid	7/8/2021	6.5	ppt	2	NA
SW 20	EPA 537	Perfluorohexanesulfonic acid	7/8/2021	20	ppt	2	NA
SW 20	EPA 537	Perfluorohexanoic acid	7/8/2021	12	ppt	2	NA
SW 20	EPA 537	Perfluorononanoic acid	7/8/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorooctanesulfonic acid	7/8/2021	33	ppt	2	10
SW 20	EPA 537	Perfluorooctanoic acid	7/8/2021	11	ppt	2	10
SW 20	EPA 537	Perfluorotetradecanoic acid	7/8/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorotridecanoic acid	7/8/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluoroundecanoic acid	7/8/2021	0	ppt	2	NA
SW 20	EPA 522	1,4-Dioxane	10/5/2021	0	ppb	0.07	1
SW 20	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/5/2021	0	ppt	2	NA
SW 20	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/5/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorobutanesulfonic acid	10/5/2021	4.4	ppt	2	NA
SW 20	EPA 537	Perfluorodecanoic acid	10/5/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorododecanoic acid	10/5/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluoroheptanoic acid	10/5/2021	6.5	ppt	2	NA
SW 20	EPA 537	Perfluorohexanesulfonic acid	10/5/2021	20	ppt	2	NA
SW 20	EPA 537	Perfluorohexanoic acid	10/5/2021	11	ppt	2	NA
SW 20	EPA 537	Perfluorononanoic acid	10/5/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorooctanesulfonic acid	10/5/2021	32	ppt	2	10
SW 20	EPA 537	Perfluorooctanoic acid	10/5/2021	11	ppt	2	10
SW 20	EPA 537	Perfluorotetradecanoic acid	10/5/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluorotridecanoic acid	10/5/2021	0	ppt	2	NA
SW 20	EPA 537	Perfluoroundecanoic acid	10/5/2021	0	ppt	2	NA
SW 23	EPA 522	1,4-Dioxane	10/1/2020	0	ppb	0.07	1
SW 23	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/1/2020	0	ppt	2	NA
SW 23	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/1/2020	0	ppt	2	NA
SW 23	EPA 537	Perfluorobutanesulfonic acid	10/1/2020	3.5	ppt	2	NA
SW 23	EPA 537	Perfluorodecanoic acid	10/1/2020	0	ppt	2	NA
SW 23	EPA 537	Perfluorododecanoic acid	10/1/2020	0	ppt	2	NA
SW 23	EPA 537	Perfluoroheptanoic acid	10/1/2020	2.7	ppt	2	NA
SW 23	EPA 537	Perfluorohexanesulfonic acid	10/1/2020	2.6	ppt	2	NA
SW 23	EPA 537	Perfluorohexanoic acid	10/1/2020	2.6	ppt	2	NA
SW 23	EPA 537	Perfluorononanoic acid	10/1/2020	0	ppt	2	NA
SW 23	EPA 537	Perfluorooctanesulfonic acid	10/1/2020	6.4	ppt	2	10
SW 23	EPA 537	Perfluorooctanoic acid	10/1/2020	13	ppt	2	10
SW 23	EPA 537	Perfluorotetradecanoic acid	10/1/2020	0	ppt	2	NA
SW 23	EPA 537	Perfluorotridecanoic acid	10/1/2020	0	ppt	2	NA
SW 23	EPA 537	Perfluoroundecanoic acid	10/1/2020	0	ppt	2	NA
SW 23	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/15/2020	0	ppt	2	NA
SW 23	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/15/2020	0	ppt	2	NA
SW 23	EPA 537	Perfluorobutanesulfonic acid	10/15/2020	4.2	ppt	2	NA
SW 23	EPA 537	Perfluorodecanoic acid	10/15/2020	0	ppt	2	NA
SW 23	EPA 537	Perfluorododecanoic acid	10/15/2020	0	ppt	2	NA



SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 23	EPA 537	Perfluoroheptanoic acid	10/15/2020	2.6	ppt	2	NA
SW 23	EPA 537	Perfluorohexanesulfonic acid	10/15/2020	2.6	ppt	2	NA
SW 23	EPA 537	Perfluorohexanoic acid	10/15/2020	2.6	ppt	2	NA
SW 23	EPA 537	Perfluorononanoic acid	10/15/2020	0	ppt	2	NA
SW 23	EPA 537	Perfluorooctanesulfonic acid	10/15/2020	6.7	ppt	2	10
SW 23	EPA 537	Perfluorooctanoic acid	10/15/2020	12	ppt	2	10
SW 23	EPA 537	Perfluorotetradecanoic acid	10/15/2020	0	ppt	2	NA
SW 23	EPA 537	Perfluorotridecanoic acid	10/15/2020	0	ppt	2	NA
SW 23	EPA 537	Perfluoroundecanoic acid	10/15/2020	0	ppt	2	NA
SW 23	EPA 522	1,4-Dioxane	1/12/2021	0	ppb	0.07	1
SW 23	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/12/2021	0	ppt	2	NA
SW 23	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/12/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorobutanesulfonic acid	1/12/2021	4.1	ppt	2	NA
SW 23	EPA 537	Perfluorodecanoic acid	1/12/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorododecanoic acid	1/12/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluoroheptanoic acid	1/12/2021	2.1	ppt	2	NA
SW 23	EPA 537	Perfluorohexanesulfonic acid	1/12/2021	2.5	ppt	2	NA
SW 23	EPA 537	Perfluorohexanoic acid	1/12/2021	2.1	ppt	2	NA
SW 23	EPA 537	Perfluorononanoic acid	1/12/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorooctanesulfonic acid	1/12/2021	6.4	ppt	2	10
SW 23	EPA 537	Perfluorooctanoic acid	1/12/2021	11	ppt	2	10
SW 23	EPA 537	Perfluorotetradecanoic acid	1/12/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorotridecanoic acid	1/12/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluoroundecanoic acid	1/12/2021	0	ppt	2	NA
SW 23	EPA 522	1,4-Dioxane	4/13/2021	0	ppb	0.07	1
SW 23	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/13/2021	0	ppt	2	NA
SW 23	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/13/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorobutanesulfonic acid	4/13/2021	4.1	ppt	2	NA
SW 23	EPA 537	Perfluorodecanoic acid	4/13/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorododecanoic acid	4/13/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluoroheptanoic acid	4/13/2021	2.6	ppt	2	NA
SW 23	EPA 537	Perfluorohexanesulfonic acid	4/13/2021	2.3	ppt	2	NA
SW 23	EPA 537	Perfluorohexanoic acid	4/13/2021	2.4	ppt	2	NA
SW 23	EPA 537	Perfluorononanoic acid	4/13/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorooctanesulfonic acid	4/13/2021	6.3	ppt	2	10
SW 23	EPA 537	Perfluorooctanoic acid	4/13/2021	12	ppt	2	10
SW 23	EPA 537	Perfluorotetradecanoic acid	4/13/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorotridecanoic acid	4/13/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluoroundecanoic acid	4/13/2021	0	ppt	2	NA
SW 23	EPA 522	1,4-Dioxane	7/7/2021	0	ppb	0.07	1
SW 23	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/7/2021	0	ppt	2	NA
SW 23	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/7/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorobutanesulfonic acid	7/7/2021	4.4	ppt	2	NA
SW 23	EPA 537	Perfluorodecanoic acid	7/7/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorododecanoic acid	7/7/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluoroheptanoic acid	7/7/2021	2.3	ppt	2	NA
SW 23	EPA 537	Perfluorohexanesulfonic acid	7/7/2021	2.3	ppt	2	NA
SW 23	EPA 537	Perfluorohexanoic acid	7/7/2021	2.3	ppt	2	NA
SW 23	EPA 537	Perfluorononanoic acid	7/7/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorooctanesulfonic acid	7/7/2021	5.9	ppt	2	10
SW 23	EPA 537	Perfluorooctanoic acid	7/7/2021	10	ppt	2	10
SW 23	EPA 537	Perfluorotetradecanoic acid	7/7/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorotridecanoic acid	7/7/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluoroundecanoic acid	7/7/2021	0	ppt	2	NA
SW 3	EPA 522	1,4-Dioxane	10/2/2020	0.091	ppb	0.07	1
SW 3	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 3	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 3	EPA 537	Perfluorobutanesulfonic acid	10/2/2020	5.4	ppt	2	NA
SW 3	EPA 537	Perfluorodecanoic acid	10/2/2020	0	ppt	2	NA
SW 3	EPA 537	Perfluorododecanoic acid	10/2/2020	0	ppt	2	NA
SW 3	EPA 537	Perfluoroheptanoic acid	10/2/2020	3.2	ppt	2	NA
SW 3	EPA 537	Perfluorohexanesulfonic acid	10/2/2020	2.3	ppt	2	NA
SW 3	EPA 537	Perfluorohexanoic acid	10/2/2020	4.8	ppt	2	NA
SW 3	EPA 537	Perfluorononanoic acid	10/2/2020	2.9	ppt	2	NA

SUEZ Water New York, Inc. - Rockland County  
 PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 3	EPA 537	Perfluorooctanesulfonic acid	10/2/2020	6.4	ppt	2	10
SW 3	EPA 537	Perfluorooctanoic acid	10/2/2020	12	ppt	2	10
SW 3	EPA 537	Perfluorotetradecanoic acid	10/2/2020	0	ppt	2	NA
SW 3	EPA 537	Perfluorotridecanoic acid	10/2/2020	0	ppt	2	NA
SW 3	EPA 537	Perfluoroundecanoic acid	10/2/2020	0	ppt	2	NA
SW 3	EPA 522	1,4-Dioxane	10/7/2020	0.088	ppb	0.07	1
SW 3	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/7/2020	0	ppt	2	NA
SW 3	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/7/2020	0	ppt	2	NA
SW 3	EPA 537	Perfluorobutanesulfonic acid	10/7/2020	4.1	ppt	2	NA
SW 3	EPA 537	Perfluorodecanoic acid	10/7/2020	0	ppt	2	NA
SW 3	EPA 537	Perfluorododecanoic acid	10/7/2020	0	ppt	2	NA
SW 3	EPA 537	Perfluoroheptanoic acid	10/7/2020	2.9	ppt	2	NA
SW 3	EPA 537	Perfluorohexanesulfonic acid	10/7/2020	2.2	ppt	2	NA
SW 3	EPA 537	Perfluorohexanoic acid	10/7/2020	4.1	ppt	2	NA
SW 3	EPA 537	Perfluorononanoic acid	10/7/2020	2	ppt	2	NA
SW 3	EPA 537	Perfluorooctanesulfonic acid	10/7/2020	5.5	ppt	2	10
SW 3	EPA 537	Perfluorooctanoic acid	10/7/2020	10	ppt	2	10
SW 3	EPA 537	Perfluorotetradecanoic acid	10/7/2020	0	ppt	2	NA
SW 3	EPA 537	Perfluorotridecanoic acid	10/7/2020	0	ppt	2	NA
SW 3	EPA 537	Perfluoroundecanoic acid	10/7/2020	0	ppt	2	NA
SW 3	EPA 522	1,4-Dioxane	1/13/2021	0.071	ppb	0.07	1
SW 3	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 3	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluorobutanesulfonic acid	1/13/2021	4.6	ppt	2	NA
SW 3	EPA 537	Perfluorodecanoic acid	1/13/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluorododecanoic acid	1/13/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluoroheptanoic acid	1/13/2021	2.5	ppt	2	NA
SW 3	EPA 537	Perfluorohexanesulfonic acid	1/13/2021	2.2	ppt	2	NA
SW 3	EPA 537	Perfluorohexanoic acid	1/13/2021	3.9	ppt	2	NA
SW 3	EPA 537	Perfluorononanoic acid	1/13/2021	2	ppt	2	NA
SW 3	EPA 537	Perfluorooctanesulfonic acid	1/13/2021	6.1	ppt	2	10
SW 3	EPA 537	Perfluorooctanoic acid	1/13/2021	10	ppt	2	10
SW 3	EPA 537	Perfluorotetradecanoic acid	1/13/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluorotridecanoic acid	1/13/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluoroundecanoic acid	1/13/2021	0	ppt	2	NA
SW 3	EPA 522	1,4-Dioxane	6/10/2021	0.078	ppb	0.07	1
SW 3	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	6/10/2021	0	ppt	2	NA
SW 3	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	6/10/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluorobutanesulfonic acid	6/10/2021	4.9	ppt	2	NA
SW 3	EPA 537	Perfluorodecanoic acid	6/10/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluorododecanoic acid	6/10/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluoroheptanoic acid	6/10/2021	3.4	ppt	2	NA
SW 3	EPA 537	Perfluorohexanesulfonic acid	6/10/2021	2.7	ppt	2	NA
SW 3	EPA 537	Perfluorohexanoic acid	6/10/2021	5	ppt	2	NA
SW 3	EPA 537	Perfluorononanoic acid	6/10/2021	4.2	ppt	2	NA
SW 3	EPA 537	Perfluorooctanesulfonic acid	6/10/2021	7.6	ppt	2	10
SW 3	EPA 537	Perfluorooctanoic acid	6/10/2021	12	ppt	2	10
SW 3	EPA 537	Perfluorotetradecanoic acid	6/10/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluorotridecanoic acid	6/10/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluoroundecanoic acid	6/10/2021	0	ppt	2	NA
SW 3	EPA 522	1,4-Dioxane	7/8/2021	0	ppb	0.07	1
SW 3	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 3	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluorobutanesulfonic acid	7/8/2021	4.8	ppt	2	NA
SW 3	EPA 537	Perfluorodecanoic acid	7/8/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluorododecanoic acid	7/8/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluoroheptanoic acid	7/8/2021	2.8	ppt	2	NA
SW 3	EPA 537	Perfluorohexanesulfonic acid	7/8/2021	2.4	ppt	2	NA
SW 3	EPA 537	Perfluorohexanoic acid	7/8/2021	4	ppt	2	NA
SW 3	EPA 537	Perfluorononanoic acid	7/8/2021	3	ppt	2	NA
SW 3	EPA 537	Perfluorooctanesulfonic acid	7/8/2021	5.9	ppt	2	10
SW 3	EPA 537	Perfluorooctanoic acid	7/8/2021	10	ppt	2	10
SW 3	EPA 537	Perfluorotetradecanoic acid	7/8/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluorotridecanoic acid	7/8/2021	0	ppt	2	NA

SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 3	EPA 537	Perfluoroundecanoic acid	7/8/2021	0	ppt	2	NA
SW 30	EPA 522	1,4-Dioxane	10/1/2020	0.076	ppb	0.07	1
SW 30	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/1/2020	0	ppt	2	NA
SW 30	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/1/2020	0	ppt	2	NA
SW 30	EPA 537	Perfluorobutanesulfonic acid	10/1/2020	0	ppt	2	NA
SW 30	EPA 537	Perfluorodecanoic acid	10/1/2020	0	ppt	2	NA
SW 30	EPA 537	Perfluorododecanoic acid	10/1/2020	0	ppt	2	NA
SW 30	EPA 537	Perfluoroheptanoic acid	10/1/2020	0	ppt	2	NA
SW 30	EPA 537	Perfluorohexanesulfonic acid	10/1/2020	0	ppt	2	NA
SW 30	EPA 537	Perfluorohexanoic acid	10/1/2020	3.2	ppt	2	NA
SW 30	EPA 537	Perfluorononanoic acid	10/1/2020	0	ppt	2	NA
SW 30	EPA 537	Perfluorooctanesulfonic acid	10/1/2020	3.3	ppt	2	10
SW 30	EPA 537	Perfluorooctanoic acid	10/1/2020	7.2	ppt	2	10
SW 30	EPA 537	Perfluorotetradecanoic acid	10/1/2020	0	ppt	2	NA
SW 30	EPA 537	Perfluorotridecanoic acid	10/1/2020	0	ppt	2	NA
SW 30	EPA 537	Perfluoroundecanoic acid	10/1/2020	0	ppt	2	NA
SW 30	EPA 522	1,4-Dioxane	1/12/2021	0	ppb	0.07	1
SW 30	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/12/2021	0	ppt	2	NA
SW 30	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/12/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorobutanesulfonic acid	1/12/2021	2.3	ppt	2	NA
SW 30	EPA 537	Perfluorodecanoic acid	1/12/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorododecanoic acid	1/12/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluoroheptanoic acid	1/12/2021	2.6	ppt	2	NA
SW 30	EPA 537	Perfluorohexanesulfonic acid	1/12/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorohexanoic acid	1/12/2021	3	ppt	2	NA
SW 30	EPA 537	Perfluorononanoic acid	1/12/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorooctanesulfonic acid	1/12/2021	3.2	ppt	2	10
SW 30	EPA 537	Perfluorooctanoic acid	1/12/2021	11	ppt	2	10
SW 30	EPA 537	Perfluorotetradecanoic acid	1/12/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorotridecanoic acid	1/12/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluoroundecanoic acid	1/12/2021	0	ppt	2	NA
SW 30	EPA 522	1,4-Dioxane	1/13/2021	0.071	ppb	0.07	1
SW 30	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	2/5/2021	0	ppt	2	NA
SW 30	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	2/5/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorobutanesulfonic acid	2/5/2021	2.3	ppt	2	NA
SW 30	EPA 537	Perfluorodecanoic acid	2/5/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorododecanoic acid	2/5/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluoroheptanoic acid	2/5/2021	2.6	ppt	2	NA
SW 30	EPA 537	Perfluorohexanesulfonic acid	2/5/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorohexanoic acid	2/5/2021	3.1	ppt	2	NA
SW 30	EPA 537	Perfluorononanoic acid	2/5/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorooctanesulfonic acid	2/5/2021	3.1	ppt	2	10
SW 30	EPA 537	Perfluorooctanoic acid	2/5/2021	11	ppt	2	10
SW 30	EPA 537	Perfluorotetradecanoic acid	2/5/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorotridecanoic acid	2/5/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluoroundecanoic acid	2/5/2021	0	ppt	2	NA
SW 30	EPA 522	1,4-Dioxane	4/13/2021	0	ppb	0.07	1
SW 30	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/13/2021	0	ppt	2	NA
SW 30	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/13/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorobutanesulfonic acid	4/13/2021	2.6	ppt	2	NA
SW 30	EPA 537	Perfluorodecanoic acid	4/13/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorododecanoic acid	4/13/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluoroheptanoic acid	4/13/2021	3	ppt	2	NA
SW 30	EPA 537	Perfluorohexanesulfonic acid	4/13/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorohexanoic acid	4/13/2021	3.1	ppt	2	NA
SW 30	EPA 537	Perfluorononanoic acid	4/13/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorooctanesulfonic acid	4/13/2021	3.5	ppt	2	10
SW 30	EPA 537	Perfluorooctanoic acid	4/13/2021	13	ppt	2	10
SW 30	EPA 537	Perfluorotetradecanoic acid	4/13/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorotridecanoic acid	4/13/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluoroundecanoic acid	4/13/2021	0	ppt	2	NA
SW 30	EPA 522	1,4-Dioxane	7/8/2021	0	ppb	0.07	1
SW 30	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 30	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA

SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 30	EPA 537	Perfluorobutanesulfonic acid	7/8/2021	2.4	ppt	2	NA
SW 30	EPA 537	Perfluorodecanoic acid	7/8/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorododecanoic acid	7/8/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluoroheptanoic acid	7/8/2021	2.7	ppt	2	NA
SW 30	EPA 537	Perfluorohexanesulfonic acid	7/8/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorohexanoic acid	7/8/2021	3.4	ppt	2	NA
SW 30	EPA 537	Perfluorononanoic acid	7/8/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorooctanesulfonic acid	7/8/2021	2.9	ppt	2	10
SW 30	EPA 537	Perfluorooctanoic acid	7/8/2021	11	ppt	2	10
SW 30	EPA 537	Perfluorotetradecanoic acid	7/8/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorotridecanoic acid	7/8/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluoroundecanoic acid	7/8/2021	0	ppt	2	NA
SW 30	EPA 522	1,4-Dioxane	10/6/2021	0	ppb	0.07	1
SW 30	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 30	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorobutanesulfonic acid	10/6/2021	2.6	ppt	2	NA
SW 30	EPA 537	Perfluorodecanoic acid	10/6/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorododecanoic acid	10/6/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluoroheptanoic acid	10/6/2021	3	ppt	2	NA
SW 30	EPA 537	Perfluorohexanesulfonic acid	10/6/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorohexanoic acid	10/6/2021	3.7	ppt	2	NA
SW 30	EPA 537	Perfluorononanoic acid	10/6/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorooctanesulfonic acid	10/6/2021	3.2	ppt	2	10
SW 30	EPA 537	Perfluorooctanoic acid	10/6/2021	13	ppt	2	10
SW 30	EPA 537	Perfluorotetradecanoic acid	10/6/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluorotridecanoic acid	10/6/2021	0	ppt	2	NA
SW 30	EPA 537	Perfluoroundecanoic acid	10/6/2021	0	ppt	2	NA
SW 31A	EPA 522	1,4-Dioxane	10/1/2020	0	ppb	0.07	1
SW 31A	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/1/2020	0	ppt	2	NA
SW 31A	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/1/2020	0	ppt	2	NA
SW 31A	EPA 537	Perfluorobutanesulfonic acid	10/1/2020	10	ppt	2	NA
SW 31A	EPA 537	Perfluorodecanoic acid	10/1/2020	0	ppt	2	NA
SW 31A	EPA 537	Perfluorododecanoic acid	10/1/2020	0	ppt	2	NA
SW 31A	EPA 537	Perfluoroheptanoic acid	10/1/2020	8.6	ppt	2	NA
SW 31A	EPA 537	Perfluorohexanesulfonic acid	10/1/2020	4.2	ppt	2	NA
SW 31A	EPA 537	Perfluorohexanoic acid	10/1/2020	14	ppt	2	NA
SW 31A	EPA 537	Perfluorononanoic acid	10/1/2020	4.7	ppt	2	NA
SW 31A	EPA 537	Perfluorooctanesulfonic acid	10/1/2020	3.6	ppt	2	10
SW 31A	EPA 537	Perfluorooctanoic acid	10/1/2020	19	ppt	2	10
SW 31A	EPA 537	Perfluorotetradecanoic acid	10/1/2020	0	ppt	2	NA
SW 31A	EPA 537	Perfluorotridecanoic acid	10/1/2020	0	ppt	2	NA
SW 31A	EPA 537	Perfluoroundecanoic acid	10/1/2020	0	ppt	2	NA
SW 31A	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/15/2020	0	ppt	2	NA
SW 31A	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/15/2020	0	ppt	2	NA
SW 31A	EPA 537	Perfluorobutanesulfonic acid	10/15/2020	11	ppt	2	NA
SW 31A	EPA 537	Perfluorodecanoic acid	10/15/2020	0	ppt	2	NA
SW 31A	EPA 537	Perfluorododecanoic acid	10/15/2020	0	ppt	2	NA
SW 31A	EPA 537	Perfluoroheptanoic acid	10/15/2020	8.3	ppt	2	NA
SW 31A	EPA 537	Perfluorohexanesulfonic acid	10/15/2020	4.4	ppt	2	NA
SW 31A	EPA 537	Perfluorohexanoic acid	10/15/2020	15	ppt	2	NA
SW 31A	EPA 537	Perfluorononanoic acid	10/15/2020	4.8	ppt	2	NA
SW 31A	EPA 537	Perfluorooctanesulfonic acid	10/15/2020	3.8	ppt	2	10
SW 31A	EPA 537	Perfluorooctanoic acid	10/15/2020	19	ppt	2	10
SW 31A	EPA 537	Perfluorotetradecanoic acid	10/15/2020	0	ppt	2	NA
SW 31A	EPA 537	Perfluorotridecanoic acid	10/15/2020	0	ppt	2	NA
SW 31A	EPA 537	Perfluoroundecanoic acid	10/15/2020	0	ppt	2	NA
SW 31A	EPA 522	1,4-Dioxane	5/20/2021	0	ppb	0.07	1
SW 31A	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	5/20/2021	0	ppt	2	NA
SW 31A	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	5/20/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluorobutanesulfonic acid	5/20/2021	5.3	ppt	2	NA
SW 31A	EPA 537	Perfluorodecanoic acid	5/20/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluorododecanoic acid	5/20/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluoroheptanoic acid	5/20/2021	6.5	ppt	2	NA
SW 31A	EPA 537	Perfluorohexanesulfonic acid	5/20/2021	3.3	ppt	2	NA

SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 31A	EPA 537	Perfluorohexanoic acid	5/20/2021	8.3	ppt	2	NA
SW 31A	EPA 537	Perfluorononanoic acid	5/20/2021	7.3	ppt	2	NA
SW 31A	EPA 537	Perfluorooctanesulfonic acid	5/20/2021	4.1	ppt	2	10
SW 31A	EPA 537	Perfluorooctanoic acid	5/20/2021	18	ppt	2	10
SW 31A	EPA 537	Perfluorotetradecanoic acid	5/20/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluorotridecanoic acid	5/20/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluoroundecanoic acid	5/20/2021	0	ppt	2	NA
SW 31A	EPA 522	1,4-Dioxane	7/8/2021	0	ppb	0.07	1
SW 31A	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 31A	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluorobutanesulfonic acid	7/8/2021	4.9	ppt	2	NA
SW 31A	EPA 537	Perfluorodecanoic acid	7/8/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluorododecanoic acid	7/8/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluoroheptanoic acid	7/8/2021	5.5	ppt	2	NA
SW 31A	EPA 537	Perfluorohexanesulfonic acid	7/8/2021	3.2	ppt	2	NA
SW 31A	EPA 537	Perfluorohexanoic acid	7/8/2021	7.5	ppt	2	NA
SW 31A	EPA 537	Perfluorononanoic acid	7/8/2021	7	ppt	2	NA
SW 31A	EPA 537	Perfluorooctanesulfonic acid	7/8/2021	5.2	ppt	2	10
SW 31A	EPA 537	Perfluorooctanoic acid	7/8/2021	18	ppt	2	10
SW 31A	EPA 537	Perfluorotetradecanoic acid	7/8/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluorotridecanoic acid	7/8/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluoroundecanoic acid	7/8/2021	0	ppt	2	NA
SW 31A	EPA 522	1,4-Dioxane	10/6/2021	0	ppb	0.07	1
SW 31A	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 31A	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluorobutanesulfonic acid	10/6/2021	4.3	ppt	2	NA
SW 31A	EPA 537	Perfluorodecanoic acid	10/6/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluorododecanoic acid	10/6/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluoroheptanoic acid	10/6/2021	5.6	ppt	2	NA
SW 31A	EPA 537	Perfluorohexanesulfonic acid	10/6/2021	3.4	ppt	2	NA
SW 31A	EPA 537	Perfluorohexanoic acid	10/6/2021	7.8	ppt	2	NA
SW 31A	EPA 537	Perfluorononanoic acid	10/6/2021	7.8	ppt	2	NA
SW 31A	EPA 537	Perfluorooctanesulfonic acid	10/6/2021	5.9	ppt	2	10
SW 31A	EPA 537	Perfluorooctanoic acid	10/6/2021	18	ppt	2	10
SW 31A	EPA 537	Perfluorotetradecanoic acid	10/6/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluorotridecanoic acid	10/6/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluoroundecanoic acid	10/6/2021	0	ppt	2	NA
SW 31A	EPA 522	1,4-Dioxane	11/4/2021	0	ppb	0.07	1
SW 31A	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	11/4/2021	0	ppt	2	NA
SW 31A	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	11/4/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluorobutanesulfonic acid	11/4/2021	3.5	ppt	2	NA
SW 31A	EPA 537	Perfluorodecanoic acid	11/4/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluorododecanoic acid	11/4/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluoroheptanoic acid	11/4/2021	3.8	ppt	2	NA
SW 31A	EPA 537	Perfluorohexanesulfonic acid	11/4/2021	2.6	ppt	2	NA
SW 31A	EPA 537	Perfluorohexanoic acid	11/4/2021	5	ppt	2	NA
SW 31A	EPA 537	Perfluorononanoic acid	11/4/2021	8.3	ppt	2	NA
SW 31A	EPA 537	Perfluorooctanesulfonic acid	11/4/2021	8.9	ppt	2	10
SW 31A	EPA 537	Perfluorooctanoic acid	11/4/2021	12	ppt	2	10
SW 31A	EPA 537	Perfluorotetradecanoic acid	11/4/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluorotridecanoic acid	11/4/2021	0	ppt	2	NA
SW 31A	EPA 537	Perfluoroundecanoic acid	11/4/2021	0	ppt	2	NA
SW 38	EPA 522	1,4-Dioxane	10/2/2020	0	ppb	0.07	1
SW 38	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 38	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluorobutanesulfonic acid	10/2/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluorodecanoic acid	10/2/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluorododecanoic acid	10/2/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluoroheptanoic acid	10/2/2020	2.4	ppt	2	NA
SW 38	EPA 537	Perfluorohexanesulfonic acid	10/2/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluorohexanoic acid	10/2/2020	2.5	ppt	2	NA
SW 38	EPA 537	Perfluorononanoic acid	10/2/2020	3.7	ppt	2	NA
SW 38	EPA 537	Perfluorooctanesulfonic acid	10/2/2020	5.2	ppt	2	10
SW 38	EPA 537	Perfluorooctanoic acid	10/2/2020	11	ppt	2	10

SUEZ Water New York, Inc. - Rockland County  
 PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 38	EPA 537	Perfluorotetradecanoic acid	10/2/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluorotridecanoic acid	10/2/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluoroundecanoic acid	10/2/2020	0	ppt	2	NA
SW 38	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/15/2020	0	ppt	2	NA
SW 38	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/15/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluorobutanesulfonic acid	10/15/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluorodecanoic acid	10/15/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluorododecanoic acid	10/15/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluoroheptanoic acid	10/15/2020	2.1	ppt	2	NA
SW 38	EPA 537	Perfluorohexanesulfonic acid	10/15/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluorohexanoic acid	10/15/2020	2.3	ppt	2	NA
SW 38	EPA 537	Perfluorononanoic acid	10/15/2020	3.3	ppt	2	NA
SW 38	EPA 537	Perfluorooctanesulfonic acid	10/15/2020	5.4	ppt	2	10
SW 38	EPA 537	Perfluorooctanoic acid	10/15/2020	11	ppt	2	10
SW 38	EPA 537	Perfluorotetradecanoic acid	10/15/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluorotridecanoic acid	10/15/2020	0	ppt	2	NA
SW 38	EPA 537	Perfluoroundecanoic acid	10/15/2020	0	ppt	2	NA
SW 38	EPA 522	1,4-Dioxane	1/13/2021	0	ppb	0.07	1
SW 38	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 38	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorobutanesulfonic acid	1/13/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorodecanoic acid	1/13/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorododecanoic acid	1/13/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluoroheptanoic acid	1/13/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorohexanesulfonic acid	1/13/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorohexanoic acid	1/13/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorononanoic acid	1/13/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorooctanesulfonic acid	1/13/2021	3.6	ppt	2	10
SW 38	EPA 537	Perfluorooctanoic acid	1/13/2021	5.9	ppt	2	10
SW 38	EPA 537	Perfluorotetradecanoic acid	1/13/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorotridecanoic acid	1/13/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluoroundecanoic acid	1/13/2021	0	ppt	2	NA
SW 38	EPA 522	1,4-Dioxane	4/14/2021	0	ppb	0.07	1
SW 38	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 38	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorobutanesulfonic acid	4/14/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorodecanoic acid	4/14/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorododecanoic acid	4/14/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluoroheptanoic acid	4/14/2021	2.2	ppt	2	NA
SW 38	EPA 537	Perfluorohexanesulfonic acid	4/14/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorohexanoic acid	4/14/2021	2	ppt	2	NA
SW 38	EPA 537	Perfluorononanoic acid	4/14/2021	3.2	ppt	2	NA
SW 38	EPA 537	Perfluorooctanesulfonic acid	4/14/2021	5.5	ppt	2	10
SW 38	EPA 537	Perfluorooctanoic acid	4/14/2021	11	ppt	2	10
SW 38	EPA 537	Perfluorotetradecanoic acid	4/14/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorotridecanoic acid	4/14/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluoroundecanoic acid	4/14/2021	0	ppt	2	NA
SW 38	EPA 522	1,4-Dioxane	7/7/2021	0	ppb	0.07	1
SW 38	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/7/2021	0	ppt	2	NA
SW 38	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/7/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorobutanesulfonic acid	7/7/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorodecanoic acid	7/7/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorododecanoic acid	7/7/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluoroheptanoic acid	7/7/2021	2	ppt	2	NA
SW 38	EPA 537	Perfluorohexanesulfonic acid	7/7/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorohexanoic acid	7/7/2021	2.1	ppt	2	NA
SW 38	EPA 537	Perfluorononanoic acid	7/7/2021	3.7	ppt	2	NA
SW 38	EPA 537	Perfluorooctanesulfonic acid	7/7/2021	5.2	ppt	2	10
SW 38	EPA 537	Perfluorooctanoic acid	7/7/2021	11	ppt	2	10
SW 38	EPA 537	Perfluorotetradecanoic acid	7/7/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorotridecanoic acid	7/7/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluoroundecanoic acid	7/7/2021	0	ppt	2	NA
SW 4	EPA 522	1,4-Dioxane	10/2/2020	0.1	ppb	0.07	1
SW 4	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA

SUEZ Water New York, Inc. - Rockland County  
 PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 4	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluorobutanesulfonic acid	10/2/2020	2.7	ppt	2	NA
SW 4	EPA 537	Perfluorodecanoic acid	10/2/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluorododecanoic acid	10/2/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluoroheptanoic acid	10/2/2020	2	ppt	2	NA
SW 4	EPA 537	Perfluorohexanesulfonic acid	10/2/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluorohexanoic acid	10/2/2020	2.9	ppt	2	NA
SW 4	EPA 537	Perfluorononanoic acid	10/2/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluorooctanesulfonic acid	10/2/2020	3.9	ppt	2	10
SW 4	EPA 537	Perfluorooctanoic acid	10/2/2020	8	ppt	2	10
SW 4	EPA 537	Perfluorotetradecanoic acid	10/2/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluorotridecanoic acid	10/2/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluoroundecanoic acid	10/2/2020	0	ppt	2	NA
SW 4	EPA 522	1,4-Dioxane	10/7/2020	0.092	ppb	0.07	1
SW 4	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/7/2020	0	ppt	2	NA
SW 4	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/7/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluorobutanesulfonic acid	10/7/2020	2.2	ppt	2	NA
SW 4	EPA 537	Perfluorodecanoic acid	10/7/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluorododecanoic acid	10/7/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluoroheptanoic acid	10/7/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluorohexanesulfonic acid	10/7/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluorohexanoic acid	10/7/2020	2.3	ppt	2	NA
SW 4	EPA 537	Perfluorononanoic acid	10/7/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluorooctanesulfonic acid	10/7/2020	3.1	ppt	2	10
SW 4	EPA 537	Perfluorooctanoic acid	10/7/2020	7	ppt	2	10
SW 4	EPA 537	Perfluorotetradecanoic acid	10/7/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluorotridecanoic acid	10/7/2020	0	ppt	2	NA
SW 4	EPA 537	Perfluoroundecanoic acid	10/7/2020	0	ppt	2	NA
SW 4	EPA 522	1,4-Dioxane	1/13/2021	0.076	ppb	0.07	1
SW 4	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 4	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorobutanesulfonic acid	1/13/2021	2.5	ppt	2	NA
SW 4	EPA 537	Perfluorodecanoic acid	1/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorododecanoic acid	1/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluoroheptanoic acid	1/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorohexanesulfonic acid	1/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorohexanoic acid	1/13/2021	2.4	ppt	2	NA
SW 4	EPA 537	Perfluorononanoic acid	1/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorooctanesulfonic acid	1/13/2021	3.7	ppt	2	10
SW 4	EPA 537	Perfluorooctanoic acid	1/13/2021	7.2	ppt	2	10
SW 4	EPA 537	Perfluorotetradecanoic acid	1/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorotridecanoic acid	1/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluoroundecanoic acid	1/13/2021	0	ppt	2	NA
SW 4	EPA 522	1,4-Dioxane	4/14/2021	0	ppb	0.07	1
SW 4	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 4	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorobutanesulfonic acid	4/14/2021	3.8	ppt	2	NA
SW 4	EPA 537	Perfluorodecanoic acid	4/14/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorododecanoic acid	4/14/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluoroheptanoic acid	4/14/2021	3.4	ppt	2	NA
SW 4	EPA 537	Perfluorohexanesulfonic acid	4/14/2021	2.5	ppt	2	NA
SW 4	EPA 537	Perfluorohexanoic acid	4/14/2021	4.5	ppt	2	NA
SW 4	EPA 537	Perfluorononanoic acid	4/14/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorooctanesulfonic acid	4/14/2021	6.7	ppt	2	10
SW 4	EPA 537	Perfluorooctanoic acid	4/14/2021	12	ppt	2	10
SW 4	EPA 537	Perfluorotetradecanoic acid	4/14/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorotridecanoic acid	4/14/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluoroundecanoic acid	4/14/2021	0	ppt	2	NA
SW 4	EPA 522	1,4-Dioxane	5/13/2021	0	ppb	0.07	1
SW 4	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	5/13/2021	0	ppt	2	NA
SW 4	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	5/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorobutanesulfonic acid	5/13/2021	3.3	ppt	2	NA
SW 4	EPA 537	Perfluorodecanoic acid	5/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorododecanoic acid	5/13/2021	0	ppt	2	NA

SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 4	EPA 537	Perfluoroheptanoic acid	5/13/2021	2.2	ppt	2	NA
SW 4	EPA 537	Perfluorohexanesulfonic acid	5/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorohexanoic acid	5/13/2021	3.4	ppt	2	NA
SW 4	EPA 537	Perfluorononanoic acid	5/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorooctanesulfonic acid	5/13/2021	4.9	ppt	2	10
SW 4	EPA 537	Perfluorooctanoic acid	5/13/2021	8.9	ppt	2	10
SW 4	EPA 537	Perfluorotetradecanoic acid	5/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorotridecanoic acid	5/13/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluoroundecanoic acid	5/13/2021	0	ppt	2	NA
SW 4	EPA 522	1,4-Dioxane	7/8/2021	0.074	ppb	0.07	1
SW 4	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 4	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorobutanesulfonic acid	7/8/2021	2.2	ppt	2	NA
SW 4	EPA 537	Perfluorodecanoic acid	7/8/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorododecanoic acid	7/8/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluoroheptanoic acid	7/8/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorohexanesulfonic acid	7/8/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorohexanoic acid	7/8/2021	2.1	ppt	2	NA
SW 4	EPA 537	Perfluorononanoic acid	7/8/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorooctanesulfonic acid	7/8/2021	2.8	ppt	2	10
SW 4	EPA 537	Perfluorooctanoic acid	7/8/2021	6.2	ppt	2	10
SW 4	EPA 537	Perfluorotetradecanoic acid	7/8/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorotridecanoic acid	7/8/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluoroundecanoic acid	7/8/2021	0	ppt	2	NA
SW 4	EPA 522	1,4-Dioxane	11/4/2021	0.092	ppb	0.07	1
SW 4	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	11/4/2021	0	ppt	2	NA
SW 4	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	11/4/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorobutanesulfonic acid	11/4/2021	2.1	ppt	2	NA
SW 4	EPA 537	Perfluorodecanoic acid	11/4/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorododecanoic acid	11/4/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluoroheptanoic acid	11/4/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorohexanesulfonic acid	11/4/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorohexanoic acid	11/4/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorononanoic acid	11/4/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorooctanesulfonic acid	11/4/2021	2.6	ppt	2	10
SW 4	EPA 537	Perfluorooctanoic acid	11/4/2021	5.7	ppt	2	10
SW 4	EPA 537	Perfluorotetradecanoic acid	11/4/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluorotridecanoic acid	11/4/2021	0	ppt	2	NA
SW 4	EPA 537	Perfluoroundecanoic acid	11/4/2021	0	ppt	2	NA
SW 56	EPA 522	1,4-Dioxane	10/2/2020	0	ppb	0.07	1
SW 56	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 56	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluorobutanesulfonic acid	10/2/2020	3.3	ppt	2	NA
SW 56	EPA 537	Perfluorodecanoic acid	10/2/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluorododecanoic acid	10/2/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluoroheptanoic acid	10/2/2020	3.2	ppt	2	NA
SW 56	EPA 537	Perfluorohexanesulfonic acid	10/2/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluorohexanoic acid	10/2/2020	4.5	ppt	2	NA
SW 56	EPA 537	Perfluorononanoic acid	10/2/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluorooctanesulfonic acid	10/2/2020	4.2	ppt	2	10
SW 56	EPA 537	Perfluorooctanoic acid	10/2/2020	11	ppt	2	10
SW 56	EPA 537	Perfluorotetradecanoic acid	10/2/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluorotridecanoic acid	10/2/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluoroundecanoic acid	10/2/2020	0	ppt	2	NA
SW 56	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/14/2020	0	ppt	2	NA
SW 56	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/14/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluorobutanesulfonic acid	10/14/2020	3.5	ppt	2	NA
SW 56	EPA 537	Perfluorodecanoic acid	10/14/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluorododecanoic acid	10/14/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluoroheptanoic acid	10/14/2020	3	ppt	2	NA
SW 56	EPA 537	Perfluorohexanesulfonic acid	10/14/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluorohexanoic acid	10/14/2020	4.3	ppt	2	NA
SW 56	EPA 537	Perfluorononanoic acid	10/14/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluorooctanesulfonic acid	10/14/2020	4.2	ppt	2	10



SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 56	EPA 537	Perfluorooctanoic acid	10/14/2020	10	ppt	2	10
SW 56	EPA 537	Perfluorotetradecanoic acid	10/14/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluorotridecanoic acid	10/14/2020	0	ppt	2	NA
SW 56	EPA 537	Perfluoroundecanoic acid	10/14/2020	0	ppt	2	NA
SW 56	EPA 522	1,4-Dioxane	1/13/2021	0	ppb	0.07	1
SW 56	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 56	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorobutanesulfonic acid	1/13/2021	3.1	ppt	2	NA
SW 56	EPA 537	Perfluorodecanoic acid	1/13/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorododecanoic acid	1/13/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluoroheptanoic acid	1/13/2021	3.2	ppt	2	NA
SW 56	EPA 537	Perfluorohexanesulfonic acid	1/13/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorohexanoic acid	1/13/2021	3.9	ppt	2	NA
SW 56	EPA 537	Perfluorononanoic acid	1/13/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorooctanesulfonic acid	1/13/2021	4.6	ppt	2	10
SW 56	EPA 537	Perfluorooctanoic acid	1/13/2021	11	ppt	2	10
SW 56	EPA 537	Perfluorotetradecanoic acid	1/13/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorotridecanoic acid	1/13/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluoroundecanoic acid	1/13/2021	0	ppt	2	NA
SW 56	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 56	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorobutanesulfonic acid	4/14/2021	3.2	ppt	2	NA
SW 56	EPA 537	Perfluorodecanoic acid	4/14/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorododecanoic acid	4/14/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluoroheptanoic acid	4/14/2021	3.2	ppt	2	NA
SW 56	EPA 537	Perfluorohexanesulfonic acid	4/14/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorohexanoic acid	4/14/2021	4	ppt	2	NA
SW 56	EPA 537	Perfluorononanoic acid	4/14/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorooctanesulfonic acid	4/14/2021	4.8	ppt	2	10
SW 56	EPA 537	Perfluorooctanoic acid	4/14/2021	12	ppt	2	10
SW 56	EPA 537	Perfluorotetradecanoic acid	4/14/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorotridecanoic acid	4/14/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluoroundecanoic acid	4/14/2021	0	ppt	2	NA
SW 56	EPA 522	1,4-Dioxane	7/8/2021	0	ppb	0.07	1
SW 56	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 56	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorobutanesulfonic acid	7/8/2021	3.5	ppt	2	NA
SW 56	EPA 537	Perfluorodecanoic acid	7/8/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorododecanoic acid	7/8/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluoroheptanoic acid	7/8/2021	3.1	ppt	2	NA
SW 56	EPA 537	Perfluorohexanesulfonic acid	7/8/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorohexanoic acid	7/8/2021	4.1	ppt	2	NA
SW 56	EPA 537	Perfluorononanoic acid	7/8/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorooctanesulfonic acid	7/8/2021	4.4	ppt	2	10
SW 56	EPA 537	Perfluorooctanoic acid	7/8/2021	11	ppt	2	10
SW 56	EPA 537	Perfluorotetradecanoic acid	7/8/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorotridecanoic acid	7/8/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluoroundecanoic acid	7/8/2021	0	ppt	2	NA
SW 56	EPA 522	1,4-Dioxane	10/6/2021	0	ppb	0.07	1
SW 56	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 56	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorobutanesulfonic acid	10/6/2021	3.3	ppt	2	NA
SW 56	EPA 537	Perfluorodecanoic acid	10/6/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorododecanoic acid	10/6/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluoroheptanoic acid	10/6/2021	3.4	ppt	2	NA
SW 56	EPA 537	Perfluorohexanesulfonic acid	10/6/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorohexanoic acid	10/6/2021	4.4	ppt	2	NA
SW 56	EPA 537	Perfluorononanoic acid	10/6/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorooctanesulfonic acid	10/6/2021	4.7	ppt	2	10
SW 56	EPA 537	Perfluorooctanoic acid	10/6/2021	12	ppt	2	10
SW 56	EPA 537	Perfluorotetradecanoic acid	10/6/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluorotridecanoic acid	10/6/2021	0	ppt	2	NA
SW 56	EPA 537	Perfluoroundecanoic acid	10/6/2021	0	ppt	2	NA
SW 70	EPA 522	1,4-Dioxane	10/2/2020	0	ppb	0.07	1

SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 70	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 70	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/2/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluorobutanesulfonic acid	10/2/2020	2.6	ppt	2	NA
SW 70	EPA 537	Perfluorodecanoic acid	10/2/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluorododecanoic acid	10/2/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluoroheptanoic acid	10/2/2020	2.2	ppt	2	NA
SW 70	EPA 537	Perfluorohexanesulfonic acid	10/2/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluorohexanoic acid	10/2/2020	2.3	ppt	2	NA
SW 70	EPA 537	Perfluorononanoic acid	10/2/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluorooctanesulfonic acid	10/2/2020	4.7	ppt	2	10
SW 70	EPA 537	Perfluorooctanoic acid	10/2/2020	11	ppt	2	10
SW 70	EPA 537	Perfluorotetradecanoic acid	10/2/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluorotridecanoic acid	10/2/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluoroundecanoic acid	10/2/2020	0	ppt	2	NA
SW 70	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/14/2020	0	ppt	2	NA
SW 70	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/14/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluorobutanesulfonic acid	10/14/2020	3	ppt	2	NA
SW 70	EPA 537	Perfluorodecanoic acid	10/14/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluorododecanoic acid	10/14/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluoroheptanoic acid	10/14/2020	2.3	ppt	2	NA
SW 70	EPA 537	Perfluorohexanesulfonic acid	10/14/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluorohexanoic acid	10/14/2020	2.4	ppt	2	NA
SW 70	EPA 537	Perfluorononanoic acid	10/14/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluorooctanesulfonic acid	10/14/2020	5.4	ppt	2	10
SW 70	EPA 537	Perfluorooctanoic acid	10/14/2020	11	ppt	2	10
SW 70	EPA 537	Perfluorotetradecanoic acid	10/14/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluorotridecanoic acid	10/14/2020	0	ppt	2	NA
SW 70	EPA 537	Perfluoroundecanoic acid	10/14/2020	0	ppt	2	NA
SW 70	EPA 522	1,4-Dioxane	1/13/2021	0.096	ppb	0.07	1
SW 70	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 70	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/13/2021	0	ppt	2	NA
SW 70	EPA 537	Perfluorobutanesulfonic acid	1/13/2021	0	ppt	2	NA
SW 70	EPA 537	Perfluorodecanoic acid	1/13/2021	0	ppt	2	NA
SW 70	EPA 537	Perfluorododecanoic acid	1/13/2021	0	ppt	2	NA
SW 70	EPA 537	Perfluoroheptanoic acid	1/13/2021	0	ppt	2	NA
SW 70	EPA 537	Perfluorohexanesulfonic acid	1/13/2021	0	ppt	2	NA
SW 70	EPA 537	Perfluorohexanoic acid	1/13/2021	0	ppt	2	NA
SW 70	EPA 537	Perfluorononanoic acid	1/13/2021	0	ppt	2	NA
SW 70	EPA 537	Perfluorooctanesulfonic acid	1/13/2021	0	ppt	2	10
SW 70	EPA 537	Perfluorooctanoic acid	1/13/2021	3.6	ppt	2	10
SW 70	EPA 537	Perfluorotetradecanoic acid	1/13/2021	0	ppt	2	NA
SW 70	EPA 537	Perfluorotridecanoic acid	1/13/2021	0	ppt	2	NA
SW 70	EPA 537	Perfluoroundecanoic acid	1/13/2021	0	ppt	2	NA
SW 82	EPA 522	1,4-Dioxane	10/1/2020	0	ppb	0.07	1
SW 82	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/1/2020	0	ppt	2	NA
SW 82	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/1/2020	0	ppt	2	NA
SW 82	EPA 537	Perfluorobutanesulfonic acid	10/1/2020	3.7	ppt	2	NA
SW 82	EPA 537	Perfluorodecanoic acid	10/1/2020	0	ppt	2	NA
SW 82	EPA 537	Perfluorododecanoic acid	10/1/2020	0	ppt	2	NA
SW 82	EPA 537	Perfluoroheptanoic acid	10/1/2020	2.7	ppt	2	NA
SW 82	EPA 537	Perfluorohexanesulfonic acid	10/1/2020	2.8	ppt	2	NA
SW 82	EPA 537	Perfluorohexanoic acid	10/1/2020	3.7	ppt	2	NA
SW 82	EPA 537	Perfluorononanoic acid	10/1/2020	0	ppt	2	NA
SW 82	EPA 537	Perfluorooctanesulfonic acid	10/1/2020	5.3	ppt	2	10
SW 82	EPA 537	Perfluorooctanoic acid	10/1/2020	12	ppt	2	10
SW 82	EPA 537	Perfluorotetradecanoic acid	10/1/2020	0	ppt	2	NA
SW 82	EPA 537	Perfluorotridecanoic acid	10/1/2020	0	ppt	2	NA
SW 82	EPA 537	Perfluoroundecanoic acid	10/1/2020	0	ppt	2	NA
SW 82	EPA 522	1,4-Dioxane	1/12/2021	0	ppb	0.07	1
SW 82	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/12/2021	0	ppt	2	NA
SW 82	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/12/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorobutanesulfonic acid	1/12/2021	4.2	ppt	2	NA
SW 82	EPA 537	Perfluorodecanoic acid	1/12/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorododecanoic acid	1/12/2021	0	ppt	2	NA

SUEZ Water New York, Inc. - Rockland County  
 PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 82	EPA 537	Perfluoroheptanoic acid	1/12/2021	2.8	ppt	2	NA
SW 82	EPA 537	Perfluorohexanesulfonic acid	1/12/2021	2.9	ppt	2	NA
SW 82	EPA 537	Perfluorohexanoic acid	1/12/2021	3.7	ppt	2	NA
SW 82	EPA 537	Perfluorononanoic acid	1/12/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorooctanesulfonic acid	1/12/2021	5.2	ppt	2	10
SW 82	EPA 537	Perfluorooctanoic acid	1/12/2021	12	ppt	2	10
SW 82	EPA 537	Perfluorotetradecanoic acid	1/12/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorotridecanoic acid	1/12/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluoroundecanoic acid	1/12/2021	0	ppt	2	NA
SW 82	EPA 522	1,4-Dioxane	4/14/2021	0	ppb	0.07	1
SW 82	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 82	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/14/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorobutanesulfonic acid	4/14/2021	4.4	ppt	2	NA
SW 82	EPA 537	Perfluorodecanoic acid	4/14/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorododecanoic acid	4/14/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluoroheptanoic acid	4/14/2021	3	ppt	2	NA
SW 82	EPA 537	Perfluorohexanesulfonic acid	4/14/2021	3	ppt	2	NA
SW 82	EPA 537	Perfluorohexanoic acid	4/14/2021	3.7	ppt	2	NA
SW 82	EPA 537	Perfluorononanoic acid	4/14/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorooctanesulfonic acid	4/14/2021	5.8	ppt	2	10
SW 82	EPA 537	Perfluorooctanoic acid	4/14/2021	12	ppt	2	10
SW 82	EPA 537	Perfluorotetradecanoic acid	4/14/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorotridecanoic acid	4/14/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluoroundecanoic acid	4/14/2021	0	ppt	2	NA
SW 82	EPA 522	1,4-Dioxane	7/8/2021	0	ppb	0.07	1
SW 82	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 82	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/8/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorobutanesulfonic acid	7/8/2021	4.1	ppt	2	NA
SW 82	EPA 537	Perfluorodecanoic acid	7/8/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorododecanoic acid	7/8/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluoroheptanoic acid	7/8/2021	3	ppt	2	NA
SW 82	EPA 537	Perfluorohexanesulfonic acid	7/8/2021	2.6	ppt	2	NA
SW 82	EPA 537	Perfluorohexanoic acid	7/8/2021	4	ppt	2	NA
SW 82	EPA 537	Perfluorononanoic acid	7/8/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorooctanesulfonic acid	7/8/2021	4.8	ppt	2	10
SW 82	EPA 537	Perfluorooctanoic acid	7/8/2021	11	ppt	2	10
SW 82	EPA 537	Perfluorotetradecanoic acid	7/8/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorotridecanoic acid	7/8/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluoroundecanoic acid	7/8/2021	0	ppt	2	NA
SW 82	EPA 522	1,4-Dioxane	10/5/2021	0	ppb	0.07	1
SW 82	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/5/2021	0	ppt	2	NA
SW 82	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/5/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorobutanesulfonic acid	10/5/2021	4.2	ppt	2	NA
SW 82	EPA 537	Perfluorodecanoic acid	10/5/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorododecanoic acid	10/5/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluoroheptanoic acid	10/5/2021	2.8	ppt	2	NA
SW 82	EPA 537	Perfluorohexanesulfonic acid	10/5/2021	2.7	ppt	2	NA
SW 82	EPA 537	Perfluorohexanoic acid	10/5/2021	3.7	ppt	2	NA
SW 82	EPA 537	Perfluorononanoic acid	10/5/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorooctanesulfonic acid	10/5/2021	5.2	ppt	2	10
SW 82	EPA 537	Perfluorooctanoic acid	10/5/2021	12	ppt	2	10
SW 82	EPA 537	Perfluorotetradecanoic acid	10/5/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluorotridecanoic acid	10/5/2021	0	ppt	2	NA
SW 82	EPA 537	Perfluoroundecanoic acid	10/5/2021	0	ppt	2	NA
SW 1A	EPA 522	1,4-Dioxane	10/6/2021	0	ppb	0.07	1
SW 1A	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 1A	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorobutanesulfonic acid	10/6/2021	4.8	ppt	2	NA
SW 1A	EPA 537	Perfluorodecanoic acid	10/6/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorododecanoic acid	10/6/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluoroheptanoic acid	10/6/2021	3.4	ppt	2	NA
SW 1A	EPA 537	Perfluorohexanesulfonic acid	10/6/2021	2.6	ppt	2	NA
SW 1A	EPA 537	Perfluorohexanoic acid	10/6/2021	4.8	ppt	2	NA
SW 1A	EPA 537	Perfluorononanoic acid	10/6/2021	0	ppt	2	NA

SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 1A	EPA 537	Perfluorooctanesulfonic acid	10/6/2021	7.4	ppt	2	10
SW 1A	EPA 537	Perfluorooctanoic acid	10/6/2021	12	ppt	2	10
SW 1A	EPA 537	Perfluorotetradecanoic acid	10/6/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluorotridecanoic acid	10/6/2021	0	ppt	2	NA
SW 1A	EPA 537	Perfluoroundecanoic acid	10/6/2021	0	ppt	2	NA
SW 3	EPA 522	1,4-Dioxane	10/6/2021	0	ppb	0.07	1
SW 3	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 3	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluorobutanesulfonic acid	10/6/2021	4.1	ppt	2	NA
SW 3	EPA 537	Perfluorodecanoic acid	10/6/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluorododecanoic acid	10/6/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluoroheptanoic acid	10/6/2021	2.7	ppt	2	NA
SW 3	EPA 537	Perfluorohexanesulfonic acid	10/6/2021	2.3	ppt	2	NA
SW 3	EPA 537	Perfluorohexanoic acid	10/6/2021	3.8	ppt	2	NA
SW 3	EPA 537	Perfluorononanoic acid	10/6/2021	3	ppt	2	NA
SW 3	EPA 537	Perfluorooctanesulfonic acid	10/6/2021	6.2	ppt	2	10
SW 3	EPA 537	Perfluorooctanoic acid	10/6/2021	9.7	ppt	2	10
SW 3	EPA 537	Perfluorotetradecanoic acid	10/6/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluorotridecanoic acid	10/6/2021	0	ppt	2	NA
SW 3	EPA 537	Perfluoroundecanoic acid	10/6/2021	0	ppt	2	NA
SW 17	EPA 522	1,4-Dioxane	10/6/2021	0	ppb	0.07	1
SW 17	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 17	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluorobutanesulfonic acid	10/6/2021	5.8	ppt	2	NA
SW 17	EPA 537	Perfluorodecanoic acid	10/6/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluorododecanoic acid	10/6/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluoroheptanoic acid	10/6/2021	3.8	ppt	2	NA
SW 17	EPA 537	Perfluorohexanesulfonic acid	10/6/2021	2.9	ppt	2	NA
SW 17	EPA 537	Perfluorohexanoic acid	10/6/2021	5.4	ppt	2	NA
SW 17	EPA 537	Perfluorononanoic acid	10/6/2021	3.7	ppt	2	NA
SW 17	EPA 537	Perfluorooctanesulfonic acid	10/6/2021	8.8	ppt	2	10
SW 17	EPA 537	Perfluorooctanoic acid	10/6/2021	13	ppt	2	10
SW 17	EPA 537	Perfluorotetradecanoic acid	10/6/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluorotridecanoic acid	10/6/2021	0	ppt	2	NA
SW 17	EPA 537	Perfluoroundecanoic acid	10/6/2021	0	ppt	2	NA
SW 38	EPA 522	1,4-Dioxane	10/6/2021	0	ppb	0.07	1
SW 38	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 38	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorobutanesulfonic acid	10/6/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorodecanoic acid	10/6/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorododecanoic acid	10/6/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluoroheptanoic acid	10/6/2021	2.2	ppt	2	NA
SW 38	EPA 537	Perfluorohexanesulfonic acid	10/6/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorohexanoic acid	10/6/2021	2.2	ppt	2	NA
SW 38	EPA 537	Perfluorononanoic acid	10/6/2021	3.6	ppt	2	NA
SW 38	EPA 537	Perfluorooctanesulfonic acid	10/6/2021	5.3	ppt	2	10
SW 38	EPA 537	Perfluorooctanoic acid	10/6/2021	11	ppt	2	10
SW 38	EPA 537	Perfluorotetradecanoic acid	10/6/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluorotridecanoic acid	10/6/2021	0	ppt	2	NA
SW 38	EPA 537	Perfluoroundecanoic acid	10/6/2021	0	ppt	2	NA
SW 19	EPA 522	1,4-Dioxane	10/6/2021	0	ppb	0.07	1
SW 19	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 19	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorobutanesulfonic acid	10/6/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorodecanoic acid	10/6/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorododecanoic acid	10/6/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluoroheptanoic acid	10/6/2021	2.4	ppt	2	NA
SW 19	EPA 537	Perfluorohexanesulfonic acid	10/6/2021	3.3	ppt	2	NA
SW 19	EPA 537	Perfluorohexanoic acid	10/6/2021	2.2	ppt	2	NA
SW 19	EPA 537	Perfluorononanoic acid	10/6/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorooctanesulfonic acid	10/6/2021	4.6	ppt	2	10
SW 19	EPA 537	Perfluorooctanoic acid	10/6/2021	14	ppt	2	10
SW 19	EPA 537	Perfluorotetradecanoic acid	10/6/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluorotridecanoic acid	10/6/2021	0	ppt	2	NA
SW 19	EPA 537	Perfluoroundecanoic acid	10/6/2021	0	ppt	2	NA

SUEZ Water New York, Inc. - Rockland County  
PFAS and 1,4-Dioxane Sample Results

Sample ID	Method	Analyte	Sample Date	Result	Units	MRL	MCL
SW 23	EPA 522	1,4-Dioxane	10/6/2021	0	ppb	0.07	1
SW 23	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 23	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/6/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorobutanesulfonic acid	10/6/2021	4	ppt	2	NA
SW 23	EPA 537	Perfluorodecanoic acid	10/6/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorododecanoic acid	10/6/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluoroheptanoic acid	10/6/2021	2.4	ppt	2	NA
SW 23	EPA 537	Perfluorohexanesulfonic acid	10/6/2021	2.2	ppt	2	NA
SW 23	EPA 537	Perfluorohexanoic acid	10/6/2021	2.2	ppt	2	NA
SW 23	EPA 537	Perfluorononanoic acid	10/6/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorooctanesulfonic acid	10/6/2021	5.6	ppt	2	10
SW 23	EPA 537	Perfluorooctanoic acid	10/6/2021	11	ppt	2	10
SW 23	EPA 537	Perfluorotetradecanoic acid	10/6/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluorotridecanoic acid	10/6/2021	0	ppt	2	NA
SW 23	EPA 537	Perfluoroundecanoic acid	10/6/2021	0	ppt	2	NA

**List of Abbreviations:**

MRL = Method Reporting Limit, the lowest level the laboratory analysis method can reliably detect

MCL = Maximum Contaminant Level, the regulatory limit set by the State

NA = Not applicable

ND = Not detected

ppt= parts per trillion

ppb =parts per billion